

Gas Fired Radiant Heaters

NO.	LOCATION	MANUFACTURER	MODEL	LENGTH Feet	INPUT (MBH)	OPTIONS
IH 20A	Maintenan & Repair Building - East High Bay	Superior Radiant	UA	2x10 ft long c/w U bend	40	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 21	Maintenan & Repair Building - East High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 22	Maintenan & Repair Building - East High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 25	Maintenan & Repair Building - East High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 26	Maintenan & Repair Building - East High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 27	Maintenan & Repair Building - East High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 28	Maintenan & Repair Building - East High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 30	Maintenan & Repair Building - East High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 31	Maintenan & Repair Building - East High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.

Gas Fired Radiant Heater Schedule



Project:

Transit Maintenance and Repair Building Mechanical Upgrade - East High Bay

File:

25-330-01

Designer: AJ

Date:

Mar-26

Sheet: MS-3