

Contractor's Fuel Fired Heating Appliance Inspection Report

The Manitoba Fire Code Section 2.6 requires that all heating systems, including appliances, chimneys and flue pipes be inspected annually so as not to create a hazardous condition. This inspection report is intended to provide the necessary documentation of the fuel fired heating system inspection, for review by the City of Winnipeg Fire Department.

Property Address	Contact Name
Property Address	Contact Name

Business Name

Furnace Make Model Serial Number

Fuel Type Gas Oil Propane Wood

General Inspection of all Units Checked OK Requires Attention

- 1. Thermostat
- 2. Fan / Limit Control
- 3. Fan motor
- 4. Belt / Pulleys
- 5. Burners / Pilots
- 6. Heat Exchanger
- 7. Gas Pilot Safety System
- 8. General Condition of Chimney
- 9. Vent Connector to Chimney
- 10. Chimney Cleanout
- 11. Gas Piping / Supports
- 12. Air Filter
- 13. Combustion / Fresh Air
- 14. Complete Furnace Cycle

Higher Efficiency Checked OK Requires Attention

- 15. Vent Safety Switches, Electronic Ignition Modules
- 16. Inducer Blower Motors and Exhaust Termination
- 17. Condensate System
- 18. Secondary Heat Exchanger

Boiler under 3 Horsepower Checked OK Requires Attention (126,000 BTU)

- 19. Boiler Flue-ways and Refractory
- 20. Boiler Controls for Correct Function / Setting
- 21. Relief Valves
- 22. Expansion Tank
- 23. Pump

Overall Condition of the Appliance

24. Pass Requires Repair (Comment and Time Frame) Fail / Taken Out of Service

Please email (fireinspections@winnipeg.ca) or fax (204-986-6198) copies of forms where the heating unit has failed inspection.

Technician's Comments

Business Name (Contractor) Phone

Service Technician's Name (Please Print) Fire Dept License #

Service Technician's Signature Date