



PHOTOLUMINESCENT EXIT SIGNS CHECKLIST

For installation compliance with CAN/ULC-S572 and the MBC
(complete ALL items below)

Project name: _____

Project Address: _____

Building or Electrical Permit Application #: _____

Quantity of photoluminescent exit signs installed for this project _____

1. This project is a replacement of existing exit signs or a replacement of exit sign/emergency lighting combination units only (i.e.: no additional exit signs are being installed? Yes No
2. Installed exit signs meet CAN/ULC-S572 requirements
3. Exit sign locations do not exceed the maximum viewing distances labeled on the signs
4. Exit signs duration of visibility meet the minimum requirements for the building emergency power as per MBC 3.2.7.4. Yes No
Specify MBC duration requirement: 30 minutes 1 hour 2 hours
5. External Light Source
 - a. Minimum 54 lux is provided on each exit sign face
 - b. External light source is not controlled by a (check all):
Switch Timer Motion Sensor Dimming Sys. Bldg. Mgmt. Sys.
 - c. Circuit breaker(s) is/are locked in the “on” position or accessible to authorized personnel only
 - d. Type of external light source(s) is/are as per manufacturer’s requirements

Specify: _____
6. Where photoluminescent exit signs are replacing signs that formed part of existing emergency lighting/exit sign combination units, the affected emergency lighting meet MBC requirements upon completion of the project Yes No
7. Exit signs will be installed as per the manufacturer’s mounting requirements
8. Site inspection will be performed by the engineer of record or his/her representative to confirm the above requirements have been met


Checklist completed by: _____

Company: _____

Phone: _____ Email: _____

Signed: _____ Date: _____

Engineer's Seal



Personal information is collected under the authority of The City of Winnipeg Charter Act, and is used for the administration and enforcement of The City of Winnipeg Building By-law No. 4555/87. This information will be disclosed publicly in accordance with the disclosure provisions of the Province of Manitoba - Freedom of Information and Protection of Privacy Act. If you have questions about the collection, use, or disclosure of your information, contact the Corporate FIPPA Coordinator: by mail to the City Clerk’s Department, Administration Building, 510 Main Street, Winnipeg, MB, R3B 1B9; by telephone to 311; or by email to FIPPA@winnipeg.ca.

**Submit completed form with electrical permit documents or email to
PPD-EPX@winnipeg.ca**