

Mechanical Design Summary

Project description/name and address: _____

General information:

1. This document **must** be completed and attached to the application submission. When necessary, additional analyses shall be provided and included with the submission.
2. All references refer to the Manitoba Building Code (MBC).
3. Indicate all items that are not applicable.

If a previous Mechanical Design Summary - Shell only has been submitted, confirm that the design criteria has been maintained.

Yes

Heating, Ventilating and Air-Conditioning (MBC Part 6)

Design professionals to initial their items of responsibility

Note: Mechanical systems, such as commercial cooking operations and manufacturing processes, are permitted to be excluded from the full or partial plan submission. However, separate permits are required for those mechanical systems.

MBC Section 6.3 Design and installation

MBC Subsection 6.3.1 Ventilation ASHRAE 62 Other (specify): _____

a. Use(s): _____

b. Rate(s): _____

c. Occupant Load(s): _____

d. Ventilation capacity required = _____

e. Ventilation capacity provided = _____

Mechanical HVAC design for MBC Part 5 – Environmental separation

a. Operating temperature: _____

b. Operating relative humidity range Summer: _____ Winter: _____

c. Operating static pressure: _____

d. Specified leakage rate for building: _____

Other space ventilation

a. Storage garage - 6.3.1.3 Yes N/A

b. Indoor air contaminant exhaust - 6.3.1.5 Yes N/A

c. Dust collection system – 6.9.1.2 Yes N/A

d. Welding and cutting operations (NFPA 51) – 6.9.1.2 Yes N/A

e. Crawl space/attic or roof spaces - 6.3.1.2 Yes N/A

f. Other conditions/features (specify): _____

MBC Subsection 6.3.2 Air duct systems		
a. Fire dampers (see Article 3.1.8.10) - 6.9.2.1	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
b. Smoke detector control (see Article 3.2.4.13) - 6.9.2.2	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
c. Exhaust ducts and outlets - 6.9.2.3	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
d. Interconnection of systems - 6.3.2.7	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
e. Make-up air - 6.3.2.8	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
MBC Subsection 3.1.8 Smoke or Combination Smoke/Fire Dampers (MBC 3.1.8.7. and 3.1.8.11.)		
a. Smoke or combination smoke/fire dampers	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
b. Locations of dampers required in item (a.) have been coordinated with the Electrical Engineer.	<input type="checkbox"/> Yes	
c. Smoke or combination smoke/fire dampers shown	<input type="checkbox"/> on electrical drawings	<input type="checkbox"/> on mechanical drawings
d. Smoke detector required/provided	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
MBC Subsection 6.9.3 Carbon monoxide alarms		
Note: The building does not contain a fuel-burning appliance, storage garage or other sources of carbon monoxide		<input type="checkbox"/> (check)
a. Carbon monoxide alarms - 6.9.3.1	<input type="checkbox"/> Yes	
b. Carbon monoxide alarms – (NFPA 720) 6.9.3.2.	<input type="checkbox"/> Yes	
c. Carbon monoxide alarms shown	<input type="checkbox"/> on electrical drawings	<input type="checkbox"/> on mechanical drawings
d. Carbon monoxide alarm locations required by 6.9.3.1 or 6.9.3.2 have been coordinated with the electrical engineer	<input type="checkbox"/> Yes	
MBC Subsection 3.3.6 /MFC dangerous goods Check if not applicable <input type="checkbox"/>		
a. Dangerous Goods - 3.3.6.2	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
b. Compressed flammable, toxic and oxidizing gases – 3.3.6.3	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
c. Flammable and Combustible Liquids – 3.3.6.4 (Refer to 4.1.2.1 in National Fire Code for classification)	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
d. Other hazardous processes and operations	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
Mechanical systems requiring a separate trade permit		
a. _____	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
b. _____		
c. _____		
Integration of fire protection and life safety systems (CAN/ULC-S1001) Standard for Integrated Systems Testing of Fire Protection and Life Safety Systems		
a. Building subject to CAN/ULC-S1001 standard (3.2.9.1)	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A

Other Systems

Design professionals to initial their items of responsibility

1. Repair garage/spray booths		Check if not applicable <input type="checkbox"/>	
a. Auto-body repair shop - 6.3.1.5	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A	
b. Service/repair garage (NFPA 30A) - 6.9.1.2	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A	
c. Spray booth (NFPA 33) - 6.3.1.5 and 6.9.1.2	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A	
2. Cooking equipment check		Check if not applicable <input type="checkbox"/>	
a. Ventilation of cooking equipment (NFPA 96) – 6.3.1.6	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A	
b. Fire protection of cooking equipment (ANSI/CAN//UL/ULC 300 or ULC/ORD-C1254.6) - 6.9.1.3	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A	

Fire Suppression Systems

Design professionals to initial their items of responsibility

Notes:

- Sprinkler system and/or standpipe drawings, including hydraulic calculations to be submitted under separate M2 permit (check)
- For M2 permit, Required Professional Design Certificate to be submitted with drawings, sealed signed and dated

1. Sprinkler systems		Check if not applicable <input type="checkbox"/>	
a. Sprinkler Systems (3.2.5.12) – NFPA (check applicable standard)	<input type="checkbox"/> 13 <input type="checkbox"/> 13R <input type="checkbox"/> 13D		
b. NFPA Hazard occupancy (check type):	<input type="checkbox"/> Light <input type="checkbox"/> Ordinary (group1) <input type="checkbox"/> Ordinary (group2) <input type="checkbox"/> Extra (group1) <input type="checkbox"/> Extra (group2)		
c. Type of system (check type):	<input type="checkbox"/> Wet <input type="checkbox"/> Dry <input type="checkbox"/> Other (specify) _____		
d. Building (for additions – existing building and addition) to be fully sprinklered	<input type="checkbox"/> Yes		
2. Standpipe systems check		Check if not applicable <input type="checkbox"/>	
a. Standpipe and hose system (3.2.5.8 to 3.2.5.11) - NFPA 14	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A	
3. Other fire suppression features			
a. Fire pump (see 3.2.5.18) - NFPA 20	<input type="checkbox"/> Yes	<input type="checkbox"/> N/A	
b. Individual rooms or areas required to be sprinklered or Alternative Solutions using sprinklering	<input type="checkbox"/> Yes	<input type="checkbox"/> No	

Affix seal with signature and date