



## Above Ground Tank Removal Checklist

Complete the following checklist and submit with your building permit application package.

### Tank removal details

Tank size (L):	
Product type:	

Tank size (L):	
Product type:	

Tank size (L):	
Product type:	

Tank size (L):	
Product type:	

### Check all that apply

Manitoba Fire Code 2024	Code Requirement	Complies
4.3.16.2.	Above ground tanks taken out of service or unsupervised for a period not exceeding 180 days shall have the piping from the tank capped or valves locked	<input type="checkbox"/>
4.3.16.2.	Above ground tanks taken out of service or unsupervised for a period exceeding 180 days shall have all liquid and vapours removed from the tank and piping	<input type="checkbox"/>
4.3.16.3.	Where a storage tank is to be permanently disposed of, sufficient openings shall be cut in the tank to render it unfit for further use	<input type="checkbox"/>

This checklist is not intended to replace any requirements under the Manitoba Fire Code or any City of Winnipeg By-laws. Complete requirements may be obtained by referring to the applicable bylaw or section under the Manitoba Fire Code. The permit applicant/contractor is responsible for ensuring that all applicable provisions are in compliance.

Completed by:

Petroleum Contractor:	
Signature:	
Date:	