

Manitoba Environment and Climate Change  
Environmental Compliance and Enforcement Branch  
Box 36, 14 Fultz Blvd  
Winnipeg MB R3Y 0L6

**July 25, 2025**

Attention: Ms. Yvonne Hawryliuk, Acting Director

**RE: JUNE 2025 MONITORING REPORTS FOR THE CITY OF WINNIPEG WATER POLLUTION CONTROL CENTRES**

The June 2025 Monitoring Reports for the West End Water Pollution Control Centre (WEWPCC), North End Water Pollution Control Centre (NEWPCC), and South End Water Pollution Control Centre (SEWPCC) are attached. This information is provided under compulsion of law in accordance with the requirements of Environment Act Licences (EALs) #2669 E RR, #2684 RRR and #2716 RR.

Please note the following respecting the report for EAL #2669 E RR:

1. The TSS results met the licence limit.
2. There was no cBOD5 result on June 25 due to an instrument malfunction; the cBOD5 results met the licence limit.
3. The ammonia results met the licence limit.
4. The total phosphorus and total nitrogen thirty-day rolling averages met the licence limits.
5. There was no result for pH on June 2 due to a lab error.
6. The monthly geometric means for fecal coliform and *E. coli* met the licence limits.

Please note the following respecting the report for EAL #2684 RRR:

1. The TSS results exceeded the licence limit on three days due to intermittent high flow and bypass events.
2. There were no BOD5 and cBOD5 results on June 25 due to an instrument malfunction; the cBOD5 results exceeded the licence limit on one day due to intermittent high flow and bypass events.
3. The ammonia results met the licence limit.
4. The total phosphorus thirty-day rolling average exceeded the licence limit; commissioning of NEWPCC interim phosphorus removal project is on-going.


5. The total nitrogen thirty-day rolling average exceeded the licence limits. The City will not be able to achieve the total nitrogen limits at the NEWPCC until it is fully upgraded.
6. Fecal coliform and *E.coli* were not analyzed on June 27 due to a lab error; the monthly geometric means for fecal coliform and *E. coli* met the licence limits.

Please note the following respecting the report for EAL #2716 RR:

1. The 24-hour composite from June 30 was not analyzed because the sample was frozen due to a refrigerator malfunction.
2. The TSS results met the licence limit.
3. There were no BOD5 and cBOD5 results on June 25 due to an instrument malfunction; the cBOD5 results met the licence limit.
4. The ammonia results met the licence limit.
5. The total phosphorus and total nitrogen thirty-day rolling averages met the licence limits.
6. The monthly geometric mean for *E. coli* met the licence limit.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by email at [rgrosselle@winnipeg.ca](mailto:rgrosselle@winnipeg.ca).

Yours sincerely,

A handwritten signature in cursive script that reads 'R. Grosselle'.

R. Grosselle  
Manager of Environmental Standards

NC

Enclosures

cc: T. Shanks, P. Eng. (e-mail)  
C. Carroll, P. Eng. (e-mail)