

Manitoba Environment and Climate Change
Environmental Compliance and Enforcement Branch
Box 36, 14 Fultz Blvd
Winnipeg MB R3Y 0L6

December 30, 2025

Attention: Ms. Yvonne Hawryliuk, Acting Director

RE: NOVEMBER 2025 MONITORING REPORTS FOR THE CITY OF WINNIPEG WATER POLLUTION CONTROL CENTRES

The November 2025 Monitoring Reports for the West End Water Pollution Control Centre (WEWPCC), North End Water Pollution Control Centre (NEWPCC), and South End Water Pollution Control Centre (SEWPCC) are attached. This information is provided under compulsion of law in accordance with the requirements of Environment Act Licences (EALs) #2669 E RR, #2684 RRR and #2716 RR.

Please note the following respecting the report for EAL #2669 E RR:

1. The TSS results exceeded the licence limit on 20 days due to increased wildlife activities and algae growth.
2. There was no CBOD5 result on November 27 due to a lab error; the CBOD5 results met the licence limit.
3. The ammonia results met the licence limit.
4. The total phosphorus and total nitrogen thirty-day rolling averages met the licence limits.
5. The monthly geometric means for fecal coliform and *E. coli* met the licence limits.

Please note the following respecting the report for EAL #2684 RRR:

1. The TSS results met the licence limit.
2. There were no results for BOD5 and CBOD5 on November 27 due to a lab error; the CBOD5 results met the licence limit.
3. The ammonia results exceeded the licence limit on 23 days. The City will not be able to achieve the ammonia limits at the NEWPCC year-round until it is fully upgraded.
4. The total phosphorus thirty-day rolling average exceeded the licence limit; commissioning of NEWPCC interim phosphorus removal project is on-going.
5. The total nitrogen thirty-day rolling average exceeded the licence limit. The City will not be able to achieve the total nitrogen limits at the NEWPCC until it is fully upgraded.

6. There were no results for fecal coliform and *E. coli* on November 10 due to a lab error; the monthly geometric means for fecal coliform and *E. coli* exceeded the licence limits due to the suspension of UV treatment to facilitate plant upgrades.

Please note the following respecting the report for EAL #2716 RR:

1. The TSS results met the licence limit.
2. There were no results for BOD5 and CBOD5 on November 27 due to a lab error; the cBOD5 results met the licence limit.
3. The ammonia results met the licence limit.
4. The total phosphorus and total nitrogen thirty-day rolling averages met the licence limits.
5. The monthly geometric mean for *E. coli* met the licence limit.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by email at rgrosselle@winnipeg.ca.

Yours sincerely,



M. Marsland
Acting Manager of Environmental Standards

NC

Enclosures

cc: T. Shanks, P. Eng. (e-mail)
C. Carroll, P. Eng. (e-mail)