

**City of Winnipeg
Water and Waste Department
North End Water Pollution Control Centre Monitoring Data
March, 2006**

Date	Raw Sewage	Final Effluent 24 Hour Composite										Final Effluent Grab Sample			
	Daily Flow	TSS	BOD5	cBOD5	Ammonia		Ortho Phosphorus	Total Phosphorus		Total Nitrogen		Temp	pH	Fecal Coliform	E.Coli
	ML**	(mg/L)	(mg/L)	(mg/L)	(mg/L-N)	(kg NH3-N/day)	(mg/L-P)	(mg/L-P)	(mg/L-P)*	(mg/L-N)	(mg/L-N)*	(oC)	(units)	MPN/100 mL ***	
1-Mar-06	165.1	17	26	10	31	5,120	3.23	3.0	4.7	36	41	14.5	6.87	4,300	4,300
2-Mar-06	170.8	15	32	8	32	5,470	3.30	3.8	4.7	45	41	14.5	6.65	7,500	3,800
3-Mar-06	168.6	15	28	8	33	5,560	3.63	3.8	4.7	41	41	14.5	6.82	4,300	4,300
4-Mar-06	166.8	16	62	9	32	5,340	3.92	3.8	4.6	39	41	15.0	6.86	4,300	4,300
5-Mar-06	165.8	15	23	8	32	5,310	3.93	4.0	4.6	40	41	14.5	6.92	9,300	7,500
6-Mar-06	185.5	14	24	8	30	5,570	3.69	3.7	4.6	38	40	14.5	6.80	23,000	23,000
7-Mar-06	181.7	8	22	6	29	5,270	3.31	3.7	4.6	36	40	14.5	6.82	93,000	12,000
8-Mar-06	183.9	10	27	7	28	5,150	3.41	3.9	4.5	39	40	14.5	6.84	4,300	1,500
9-Mar-06	204.5	13	25	8	30	6,140	3.41	4.0	4.5	40	40	14.5	6.81	43,000	23,000
10-Mar-06	204.9	14	30	6	27	5,530	3.06	3.5	4.5	35	40	14.5	6.84	43,000	43,000
11-Mar-06	194.1	7	14	5	29	5,630	3.32	3.3	4.4	34	40	14.0	7.02	23,000	23,000
12-Mar-06	185.1	13	27	7	30	5,550	3.71	4.0	4.4	38	40	14.0	6.97	9,300	4,300
13-Mar-06	175.5	7	21	6	30	5,270	3.91	4.3	4.3	38	40	13.5	6.87	9,300	9,300
14-Mar-06	172.1	7	26	7	30	5,160	3.87	3.6	4.2	36	39	14.0	6.80	43,000	7,500
15-Mar-06	175.9	10	24	7	30	5,280	3.90	4.5	4.1	43	39	14.5	6.78	43,000	15,000
16-Mar-06	170.6	10	36	9	30	5,120	3.85	4.5	4.1	41	39	14.5	6.77	23,000	23,000
17-Mar-06	179.6	11	29	8	32	5,750	4.34	4.7	4.1	42	39	15.0	nr	38,000	38,000
18-Mar-06	183.9	15	32	7	30	5,520	4.05	4.6	4.1	41	39	14.5	6.88	23,000	23,000
19-Mar-06	181.4	11	26	7	27	4,900	3.57	3.9	4.1	35	39	14.5	7.02	7,500	4,300
20-Mar-06	184.4	10	27	8	28	5,160	3.74	5.9	4.2	41	40	14.5	6.86	7,500	2,300
21-Mar-06	196.7	16	24	8	26	5,110	3.51	5.2	4.2	38	40	13.5	6.79	23,000	23,000
22-Mar-06	202.5	16	29	8	27	5,470	3.26	5.0	4.3	38	40	14.0	6.86	9,300	4,300
23-Mar-06	200.4	14	30	8	27	5,410	3.20	5.7	4.3	42	40	13.0	6.86	23,000	4,300
24-Mar-06	235.1	21	31	10	26	6,110	2.69	4.8	4.3	42	40	13.5	6.79	23,000	23,000
25-Mar-06	240.7	21	20	11	23	5,540	1.55	3.1	4.3	37	40	13.0	7.02	230,000	230,000
26-Mar-06	296.6	36	29	16	17	5,040	1.77	3.1	4.2	25	39	12.0	7.05	93,000	93,000
27-Mar-06	321.9	29	30	17	15	4,830	1.72	2.8	4.2	27	38	10.5	6.94	93,000	43,000
28-Mar-06	356.1	26	21	11	12	4,270	1.38	2.2	4.1	21	38	10.5	6.96	93,000	93,000
29-Mar-06	369.9	31	21	11	12	4,440	1.60	2.5	4.0	24	37	10.0	6.91	9,300	2,300
30-Mar-06	506.1	63	27	14	7	3,540	1.18	2.0	3.9	16	36	11.0	6.95	(15,000)	(15,000)
31-Mar-06	661.3	40	24	11	5	3,310	1.07	1.2	3.8	14	36	11.0	7.21	(150,000)	(93,000)
Total:	7188														
Max:	661														
Min:	165														
Average:	231.9	18	27	9	26	5,190	3.10	3.8		36		13.6	6.88		
Geo.Mean:														20,200	12,300

Notes:

- (1) effluent ammonia load based upon Raw Sewage flows and Final NH3-N concentrations
- (2) nr - not recorded or no result; na - not analyzed; ns - no sample
- (3) Where value is expressed as less than (<), the value is halved and used in the calculations.
- (4) * = 30 day rolling average

- (5)** Flow, highlighted in bold, in excess of 380 ML/D per clause 26 of Licence 2684R.
- (6) Bracketed Coliform results not used in the Geometric Mean calculation.
- (7) Raw wastewater flows in excess of 400 ML/D will by-pass the secondary process and flows in excess of 675 ML/D will cause raw sewage to by-pass the plant.
- (8) February 9 - plant shut-down for 4 hours which could affect 24 hour composite sample results for Feb. 8 and 9.