

City of Winnipeg
Water and Waste Department
South End Water Pollution Control Centre Monitoring Data
January 2009

Date	Raw Sewage	Final Effluent 24 Hour Composite										Final Effluent Grab Sample			
	Daily Flow	TSS	BOD5	cBOD5	Ammonia		Ortho Phosphorus	Total Phosphorus		Total Nitrogen		Temp.	pH	Fecal Coliform	E.Coli
	ML**	(mg/L)	(mg/L)	(mg/L)	(mg/L-N)	(kg NH3-N/day)	(mg/L-P)	(mg/L-P)	(mg/L-P)*	(mg/L-N)	(mg/L-N)*	(°C)	(units)	MPN/100 mL	
1-Jan-09	42.3	9	25	9	25	1,050	3.17	3.8	4.8	30	28	16	6.59	49	49
2-Jan-09	47.2	6	17	6	27	1,250	3.61	4.2	4.7	31	28	13	6.81	700	460
3-Jan-09	46.6	8	25	7	28	1,282	4.11	4.8	4.7	30	28	14	6.73	33	33
4-Jan-09	47.1	6	21	5	27	1,258	4.50	5.2	4.7	30	28	13	6.62	490	170
5-Jan-09	48.2	11	24	6	26	1,230	4.51	5.3	4.7	29	28	14	6.40	170	49
6-Jan-09	46.7	47	>74	15	27	1,260	5.50	7.1	4.7	34	29	15	6.44	4	4
7-Jan-09	44.7	11	26	8	27	1,210	4.76	5.6	4.8	32	29	13	6.42	39	21
8-Jan-09	49.0	12	<10	6	29	1,425	5.04	5.7	4.8	32	29	13	6.51	94	70
9-Jan-09	46.5	17	20	8	30	1,376	4.62	5.1	4.8	33	29	14	6.75	46	46
10-Jan-09	48.0	6	13	6	30	1,440	4.32	5.0	4.8	34	30	13	6.60	110	110
11-Jan-09	49.4	5	14	6	29	1,432	4.30	4.9	4.8	33	30	14	6.56	350	240
12-Jan-09	46.9	7	17	6	28	1,332	3.73	4.4	4.8	33	30	15	6.69	790	790
13-Jan-09	46.6	8	19	5	29	1,327	2.46	3.2	4.8	33	30	14	6.35	70	22
14-Jan-09	47.1	5	13	5	30	1,405	4.13	4.9	4.8	34	31	13	6.48	<2	<2
15-Jan-09	48.9	5	12	5	28	1,373	4.80	5.4	4.8	35	31	13	6.35	49	49
16-Jan-09	50.0	6	11	5	30	1,520	4.37	4.9	4.8	34	31	14	6.52	240	240
17-Jan-09	49.7	9	10	6	29	1,436	3.71	4.3	4.8	33	31	14	6.64	21	17
18-Jan-09	50.1	10	12	5	28	1,388	3.71	4.4	4.8	33	31	14	6.67	17	8
19-Jan-09	48.5	<4	11	5	28	1,343	3.60	4.1	4.8	31	32	14	6.46	79	79
20-Jan-09	45.6	6	11	5	30	1,369	3.98	4.6	4.8	34	32	14	6.46	23	13
21-Jan-09	50.0	8	<10	4	32	1,580	4.65	5.3	4.9	36	32	15	6.74	2	2
22-Jan-09	48.6	14	17	7	32	1,563	5.49	6.1	4.9	36	32	14	6.52	14	14
23-Jan-09	47.0	6	16	7	31	1,439	4.23	5.0	4.9	31	32	14	6.60	33	23
24-Jan-09	47.6	5	12	8	31	1,451	3.86	4.4	5.0	37	33	12	6.71	33	17
25-Jan-09	48.8	11	18	9	29	1,430	3.67	4.5	5.0	30	33	13	6.64	17	4
26-Jan-09	46.8	19	29	14	27	1,272	3.54	4.5	5.0	28	33	14	6.56	170	170
27-Jan-09	47.1	29	37	22	28	1,318	3.84	5.1	5.0	31	33	13	6.57	350	350
28-Jan-09	45.8	12	18	8	31	1,411	4.05	5.6	5.0	33	33	14	6.50	1,300	140
29-Jan-09	46.5	13	22	10	30	1,404	4.50	5.2	5.0	31	33	13	6.53	230	130
30-Jan-09	47.4	13	20	12	29	1,373	4.62	5.5	4.9	31	33	14	6.57	79	11
31-Jan-09	48.5	8	17	8	29	1,387	2.90	3.6	4.9	31	33	13	6.64	46	21
Max:	50.1														
Min:	42.3														
Average:	47.5	11	19	8	29	1,366	4.14	4.9		32		14	6.57		
Geo.Mean:														62	38

Notes:

- (1) effluent ammonia load based upon Raw Sewage flows and Final NH3-N concentrations
- (2) nr - not recorded or no result; na - not analyzed; ns - no sample
- (3) Where value is expressed as less than (<), the value is halved and used in the calculations.
- (4) * = 30 day rolling average
- (5)** Flow, highlighted in bold, in excess of 98.6 ML/D per clause 26 of Licence 2716.
- (6) Bracketed Coliform results not used in the Geometric Mean calculation.
- (7) Raw wastewater flows in excess of 100 ML/D will by-pass the secondary process.