



Water and Waste Department • Service des eaux et des déchets

January 24, 2006

Our Files: 040-17-08-27-00
040-17-08-15-00

Mr. Mike Van Den Bosch, P.Eng.
Environmental Assessment and Licensing Branch
Manitoba Conservation
Suite 160 – 123 Main Street
Winnipeg, Manitoba
R3C 1A5

Dear Mr. Van Den Bosch:

**RE: DECEMBER 2005 MONITORING REPORTS FOR THE WEST END WATER
POLLUTION CONTROL CENTRE LICENCE NO. 2669 E R AND THE NORTH
END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2684 R**

Attached please find the December 2005 Monitoring Reports for Licence No. 2669 E R issued for the City of Winnipeg West End Water Pollution Control Centre (WEWPCC) and Licence No. 2684 R issued for the City of Winnipeg North End Water Pollution Control Centre (NEWPCC).

Please note the following respecting the report for Licence #2669 E R:

1. On December 6, there was a quality control failure on cBOD5; the results were therefore not valid.
2. On December 13, the automatic sampler failed resulting in no sample.
3. On December 17, operating staff did not report to the plant and a sample could not be collected.
4. On December 18, the sample bottles overflowed resulting in no sample.
5. On December 24, the pH and temperature results were not recorded.
6. On December 28 and 29, a digestion error for total phosphorus resulted in no results.

Please note the following respecting the report for Licence #2684 R:

1. On December 6, there was a quality control failure on BOD5 and cBOD5; the results were therefore not valid.
2. On December 4, 20, 25 and 28, a digestion error for total phosphorus resulted in no results.
3. On December 20, a digestion error for total nitrogen resulted in no result.

The nutrient digestion errors are the result of a faulty digestion block. We are in the process of ordering a new block which should resolve this recurring problem.

Embrace the Spirit • Vivez l'esprit

Please let me know of any concerns or questions respecting this submission. I may be reached at the below address, by telephone at 986-4807 or by email at kkjartanson@winnipeg.ca.

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original signed by:

K.J.T. Kjartanson, P.Eng.
Manager of Environmental Standards

KJTK:kk:pr
Attachments

c: Cliff Lee, P.Eng., Assistant Director of Red River Region
B.D. MacBride, P.Eng.
W.J. Borlase, P.Eng.
M.A. Shkolny, P.Eng.

N:\Clerks\patsy's computer\OFFICE\word\kjt\Bosch3-ltr.doc