



Water and Waste Department • Service des eaux et des déchets

July 30, 2015

Our Files: 040-17-08-29-00
040-17-08-15-00
040-17-08-35-00

Don Labossiere
Director, Environmental Compliance and Enforcement
Manitoba Conservation and Water Stewardship
1007 Century Street
Winnipeg MB R3H 0W4

Dear Mr. Labossiere:

RE: JUNE 2015 MONITORING REPORTS FOR THE CITY OF WINNIPEG WATER POLLUTION CONTROL CENTRES, LICENCE NO. 2669 E RR, LICENCE NO. 2684 RRR AND LICENCE NO. 2716 RR

The June 2015 Monitoring Reports for Licence No. 2669 E RR issued for the City of Winnipeg West End Water Pollution Control Centre (WEWPCC), Licence No. 2684 RRR issued for the City of Winnipeg North End Water Pollution Control Centre (NEWPCC) and Licence No. 2716 RR issued for the City of Winnipeg South End Water Pollution Control Centre (SEWPCC) are attached. This information is provided under compulsion of law in accordance with the requirements under the Environment Act Licences #2669 E RR, #2684 RRR and #2716 RR.

Please note that all results reported for Licence #2669 E RR met the licence requirements in June.

Please note the following respecting the report for Licence #2684 RRR:

1. The TSS results exceeded the licence limit on 3 days in June due to intermittent high flows and bypass events.
2. The BOD5 results exceeded the licence limit on 4 days in June. On June 6 and 22, the BOD5 results exceeded the limit set in the licence due to intermittent high flows and bypass events. On June 1 and 30 the BOD5 results exceeded the licence limit; through testing we have shown that the cBOD5 and TOC results have been consistently low, therefore these high results are due to nitrification occurring.
3. The monthly geometric mean for fecal coliform and E. coli met the licence limits in June.

Please note that all results reported for Licence #2716 RR met the licence requirements in June.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by email at rgrosselle@winnipeg.ca.

Thank you for your ongoing cooperation and understanding in this matter.

Yours sincerely,
Original signed by :

R. Grosselle
Manager of Environmental Standards
Attachments

c: D. P. Sacher, P.Eng. (e-mail) C. Carroll, P.Eng. (e-mail)

N:\Compliance Reporting\WPCC Monthly\2015 Submittal Letters WPCC\2015-06 Submittal Letter WPCC Monitoring.doc

Environmental Standards Division • Division des normes environnementales
2230 Main Street • 2230, Rue Main • Winnipeg • Manitoba R2V 4T8
tel/tél. (204) 986-4684 • fax/télec. (204) 339-2147 • winnipeg.ca