



Water and Waste Department • Service des eaux et des déchets

April 30, 2015

Our Files: 040-17-08-29-00
040-17-08-15-00
040-17-08-35-00

Don Labossiere
Director, Environmental Compliance and Enforcement
Manitoba Conservation and Water Stewardship
123 Main Street
Winnipeg MB
R3C 1A5

Dear Mr. Labossiere:

RE: MARCH 2015 MONITORING REPORTS FOR THE WEST END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2669 E RR, THE NORTH END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2684 RRR AND THE SOUTH END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2716 RR

Attached please find the March 2015 Monitoring Reports for Licence No. 2669 E RR issued for the City of Winnipeg West End Water Pollution Control Centre (WEWPCC), Licence No. 2684 RRR issued for the City of Winnipeg North End Water Pollution Control Centre (NEWPCC) and Licence No. 2716 RR issued for the City of Winnipeg South End Water Pollution Control Centre (SEWPCC). This information is provided under compulsion of law in accordance with the requirements under the Environment Act Licences #2669 E RR, #2684 RRR and #2716 RR.

Please note the following respecting the report for Licence #2669 E RR:

1. The TSS results met the limit set in the licence in March.
2. The cBOD5 results met the limit set in the licence in March.
3. The ammonia results, the total nitrogen and total phosphorus thirty-day rolling averages met the limits set in the licence in March.
4. The monthly geometric mean for fecal coliform and E. coli met the limits set in the licence in March.

Please note the following respecting the report for Licence #2684 RRR:

1. The TSS results exceeded the licence limit on 11 days in March. Intermittent high flows and by-pass events contributed to some of the increased TSS results. We continue to make adjustments to plant operations in order to improve process performance.
2. The BOD5 results exceeded the limit set in the licence on 6 days in March. Intermittent high flows and by-pass events contributed to some of the increased BOD5 results. As mentioned above, adjustments continue to be made to plant operations in order to improve process performance.

3. During the month of March the E. Coli result met the limit set in the licence however the fecal coliform limit was exceeded. We are continuing to investigate the root cause of the coliform compliance issues.

Please note the following respecting the report for Licence #2716 RR:

1. The TSS results met the limit set in the licence in March.
2. The cBOD5 results met the limit set in the licence in March.
3. The monthly geometric mean for E. coli met the limit set in the licence in March.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by email at rgrosselle@winnipeg.ca.

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original signed by:

R. Grosselle
Manager of Environmental Standards

RG
Attachments

c: D. P. Sacher, P.Eng. (e-mail)
C. Carroll, P.Eng. (e-mail)

N:\Compliance Reporting\WPCC Monthly\2015 Submittal Letters WPCC\2015-03 Submittal Letter WPCC Monitoring.doc