



Water and Waste Department • Service des eaux et des déchets

Environmental Standards Division • Division des Normes Environnementales

February 28, 2017

Our File No: 040-17-08-29-00

Manitoba Sustainable Development
Environmental Compliance and Enforcement Branch
1007 Century Street
Winnipeg, MB R3H 04W

040-17-08-15-00

040-17-08-35-00

Attention: Mr. Don Labossiere, Regional Director

**RE: JANUARY 2017 MONITORING REPORTS FOR THE WEST END WATER
POLLUTION CONTROL CENTRE LICENCE NO. 2669 E RR, THE NORTH END
WATER POLLUTION CONTROL CENTRE LICENCE NO. 2684 RRR AND THE
SOUTH END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2716 RR**

The January 2017 Monitoring Reports for Licence No. 2669 E RR issued for the City of Winnipeg West End Water Pollution Control Centre (WEWPCC), Licence No. 2684 RRR issued for the City of Winnipeg North End Water Pollution Control Centre (NEWPCC) and Licence No. 2716 RR issued for the City of Winnipeg South End Water Pollution Control Centre (SEWPCC) are attached. This information is provided under compulsion of law in accordance with the requirements under the Environment Act Licences #2669 E RR, #2684 RRR and #2716 RR.

Please note the following respecting the report for Licence #2669 E RR:

1. The TSS results met the licence limit in January.
2. There was no result for cBOD5 on January 3 due to a QC failure; the cBOD5 results met the licence limit in January.
3. The ammonia results met the licence limit in January.
4. The total phosphorus and total nitrogen thirty-day rolling averages met the licence limits in January.
5. There was no pH result for the grab sample on January 2 due to a sample leak and on January 12 due to a sampling error. The monthly geometric means for fecal coliform and *E. coli* met the licence limits in January.

Please note the following respecting the report for Licence #2684 RRR:

1. The TSS results met the licence limit in January.
2. There were no results for BOD5 and cBOD5 on January 3 due to a QC failure. The BOD5 results met the licence limit in January.
3. The monthly geometric means for fecal coliform and *E. coli* met the licence limits in January.



Please note the following respecting the report for Licence #2716 RR:

1. The TSS results met the licence limit in January.
2. There were no results for BOD5 or cBOD5 on January 3 due to a QC failure and no result for cBOD5 on January 10 due to a technician error. The cBOD5 results met the licence limit in January.
3. There was no pH result for the grab sample on January 12 due to a sampling error. The monthly geometric mean for *E. coli* met the licence limit in January.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by email at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by N. Crawford for:

R. Grosselle
Manager of Environmental Standards

NC

Enclosures

cc: M. L. Geer CPA, CA (e-mail)
C. Carroll, P. Eng (e-mail)