



**Water and Waste Department • Service des eaux et des déchets**

*Environmental Standards Division • Division des Normes Environnementales*

December 29, 2017

Our File No: 040-17-08-29-00

Manitoba Sustainable Development  
Environmental Compliance and Enforcement Branch  
1007 Century Street  
Winnipeg, MB R3H 04W

040-17-08-15-00

040-17-08-35-00

EMS

Attention: Mr. Don Labossiere, Regional Director

**RE: NOVEMBER 2017 MONITORING REPORTS FOR THE WEST END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2669 E RR, THE NORTH END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2684 RRR AND THE SOUTH END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2716 RR**

---

The November 2017 Monitoring Reports for Licence No. 2669 E RR issued for the City of Winnipeg West End Water Pollution Control Centre (WEWPCC), Licence No. 2684 RRR issued for the City of Winnipeg North End Water Pollution Control Centre (NEWPCC) and Licence No. 2716 RR issued for the City of Winnipeg South End Water Pollution Control Centre (SEWPCC) are attached. This information is provided under compulsion of law in accordance with the requirements under the Environment Act Licences #2669 E RR, #2684 RRR and #2716 RR.

Please note the following respecting the report for Licence #2669 E RR:

1. The TSS results exceeded the licence limit on six days in November due to algae die off and high geese population in the polishing cells.
2. The cBOD5 and ammonia results met the licence limits in November.
3. The total phosphorus and total nitrogen thirty-day rolling averages met the licence limits in November.
4. There were no results for fecal coliform and *E. coli* on November 18 due to a technician error; the monthly geometric means for fecal coliform and *E. coli* met the licence limits in November.

Please note the following respecting the report for Licence #2684 RRR:

1. The TSS and BOD5 results met the licence limits in November.
2. There were no results for fecal coliform and *E. coli* on November 17 due to a technician error; the monthly geometric means for fecal coliform and *E. coli* met the licence limits in November.

Please note the following respecting the report for Licence #2716 RR:

1. The TSS results met the licence limit in November.
2. There were no results for cBOD5 on November 19 and 24 due to technician errors; the cBOD5 results met the licence limits in November.
3. There was no result for E.coli on November 18 due to a technician error; the monthly geometric mean for *E. coli* met the licence limit in November.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by email at [rgrosselle@winnipeg.ca](mailto:rgrosselle@winnipeg.ca).

Yours sincerely,

*Original signed by N. Crawford for:*

R. Grosselle  
Manager of Environmental Standards

NC

Enclosures

cc: M. L. Geer CPA, CA (e-mail)  
C. Carroll, P. Eng (e-mail)