



Kale Black, Sr. Drinking Water Officer  
Office of Drinking Water, Manitoba Sustainable Development  
309 – 25 Tupper Street North  
Portage La Prairie, MB R1N 3K1

October 6, 2023

**RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00**

**Incident No:** CAR-12-2023-WMR

**Reported to ODW:** September 14, 2023

**Reported by:** Louis Rivard, Superintendent of Water Distribution Operations

**Approved by:** Zeljko Bodiroga, Field Services Engineer

**Incident Date:** September 13, 2023

**Incident Location:** Winnipeg 3-Dist (WM Repair)

**Incident Type:**

1. Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

**Description of Corrective Actions:**

Water Services:

IMMEDIATELY: Contacted the ODW and Environmental Standards, and flushed the isolated area. Re-sampled original location, and tested for; bacteria, turbidity, and free chlorine until one negative bacteria result was obtained.

**Test Results:** See attached

**LIMS Reference No:** N/A

**EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING**

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Sample Name	Work Order Number	Date Sampled	E Coli (MPNU/100mL)	Total Coliform (MPNU/100mL)	Free Chlorine (mg/L)	Turbidity-field (ntu)	Time Sampled (hrs)
Hydrant - Lenore	2309403	13-Sep-23	<1	3	0.92	4.25	13:30
Hydrant - Lenore_Resample	2309941	14-Sep-23	<1	<1	0.75	4.42	15:06

NOTES/COMMENTS:  
1. All microbiological tests performed by contract laboratory.  
2. OL - Autosampler or Process Offline  
3. NA - Not Applicable