



Kale Black, Sr. Drinking Water Officer  
Office of Drinking Water, Manitoba Sustainable Development  
309 – 25 Tupper Street North  
Portage La Prairie, MB R1N 3K1

November 5, 2024

**RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00**

**Incident No:** CAR-05-2024-ESD

**Reported to ODW:** October 30, 2024

**Reported by:** Courtney Diduck, Analytical Services Branch Head

**Approved by:** Courtney Diduck, Analytical Services Branch Head

**Incident Date:** October 29, 2024

**Incident Location:** Winnipeg 3-Dist (SE08)

**Incident Type:** Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

**Description and Corrective Actions:**

Environmental Standards:

IMMEDIATELY: Contacted the ODW and re-sampled original location for bacteria, turbidity, free/total chlorine, and temperature. Monitoring was terminated after two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

**Test Results:** See attached

**Reference No:** Job\_2129

**EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING**

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Sample Name	Sample Number	Date Sampled	E Coli (MPNU/100mL)	Total Coliform (MPNU/100mL)	Heterotrophic Plate Count (CFU/mL)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity-field (ntu)	Temperature (°C)	Time Sampled (hrs)
SE08	703288	29-Oct-24	0	1	<1	0.93	1.25	0.18	12.6	13:13
SE08_Resample 1	704094	30-Oct-24	0	0	<1	0.88	1.19	NA	12.9	14:15
WC04_Resample 2	704095	31-Oct-24	0	0	<1	1.05	1.29	0.14	13.2	14:20
WC04_Resample 2 (Duplicate)	704096	31-Oct-24	0	0	<1	1.09	1.29	0.15	13.1	14:21

NOTES/COMMENTS:

1. All microbiological tests performed by contract laboratory.
2. OL - Autosampler or Process Offline
3. NA - Not Applicable or Not Analyzed