



Water and Waste
Eaux et déchets

Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

January 7, 2025

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-10-2024-WMR

Reported to ODW: December 17, 2024

Reported by: Clayton Olson, Superintendent of Water Distribution

Approved by: Zeljko Bodioga, Field Services Engineer

Incident Date: December 16, 2024

Incident Location: Winnipeg 3-Dist (WM Repair)

Incident Type: Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

Description Corrective Actions:

Water Services:

Contacted the ODW and flushed the isolated area. Re-sampled original location and tested for bacteria, turbidity, and free chlorine until two negative bacteria results were obtained.

Test Results: See attached

LIMS Reference No: N/A

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Sample Name	Work Order Number	Date Sampled	E Coli (MPNU/100mL)	Total Coliform (MPNU/100mL)	Free Chlorine (mg/L)	Turbidity-field (ntu)	Time Sampled (hrs)
Hydrant - Pacific Ave W	2413667	16-Dec-24	<1	1	0.92	1.43	15:00
Hydrant - Pacific Ave W_Resample	2413667	17-Dec-24	<1	<1	0.99	3.20	14:30
Hydrant - Pacific Ave W_Resample 2	2413667	18-Dec-24	<1	<1	1.00	0.42	13:09

NOTES/COMMENTS:

1. All microbiological tests performed by contract laboratory.
2. OL - Autosampler or Process Offline
3. NA - Not Applicable