



Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

June 6, 2025

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR_09-2025

Reported to ODW: May 17, 2025

Reported by: Courtney Diduck, Analytical Services Branch Head

Approved by: Courtney Diduck, Analytical Services Branch Head

Incident Date: May 16, 2025

Incident Location: Winnipeg 3-Dist_WMCP

Incident Type: (choose all that apply)

Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

Description of Event and Corrective Actions:

Environmental Standards:

IMMEDIATELY: Contacted the ODW and Water Services.

Water Services:

Re-flushed the affected sequence, and re-sampled original location for bacteria, turbidity, and free chlorine. Monitoring and flushing was terminated after two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

Test Results: See attached.

Reference No: Job_2308

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Sample Name	Sample Number	Date Sampled	E Coli (MPNU/100mL)	Total Coliform (MPNU/100mL)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (ntu)	Temperature (°C)	Time Sampled (hrs)
Hydrant Post Flush 2 (Seq 20)	752803	16-May-25	0	3	1.16	1.26	0.39	12.2	12:58
Hydrant Post Flush Resample	758495	17-May-25	0	0	1.09	na	0.62	na	13:00
Hydrant Post Flush Resample 2	758496	18-May-25	0	0	1.25	na	0.97	na	13:30

Notes/Comments:

1. All microbiological tests performed by contract laboratory.
2. ol - autosampler or process offline
3. na - not applicable or not analyzed