



Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

June 6, 2025

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR_10-2025

Reported to ODW: May 30, 2025

Reported by: Krista Wazny, Laboratory Supervisor

Approved by: Courtney Diduck, Analytical Services Branch Head

Incident Date: May 29, 2025

Incident Location: Winnipeg 3-Dist_WMCP

Incident Type: (choose all that apply)

Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

Description of Event and Corrective Actions:

Environmental Standards:

IMMEDIATELY: Contacted the ODW and Water Services.

Water Services:

Re-flushed the affected sequence, and re-sampled original location for bacteria, turbidity, and free chlorine. Monitoring and flushing was terminated after two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

Test Results: See attached.

Reference No: Job_2309

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Sample Name	Sample Number	Date Sampled	E Coli (MPNU/100mL)	Total Coliform (MPNU/100mL)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (ntu)	Temperature (°C)	Time Sampled (hrs)
Hydrant Post Flush 3 (Seq 108)	756239	29-May-25	0	1	0.9	1.22	2.79	13.4	14:29
Hydrant Post Flush Resample	758497	30-May-25	0	0	1.10	na	0.21	na	19:05
Hydrant Post Flush Resample 2	758498	31-May-25	0	0	1.04	na	0.21	na	17:00

Notes/Comments:

1. All microbiological tests performed by contract laboratory.
2. ol - autosampler or process offline
3. na - not applicable or not analyzed