



Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

February 5, 2026

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-01-2026-ESD

Reported to ODW: January 21, 2026

Reported by: Courtney Diduck, Laboratory Services Branch Head

Approved by: Courtney Diduck, Laboratory Services Branch Head

Incident Date: January 20, 2026

Incident Location: Winnipeg 3-Dist (NW08)

Incident Type: Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

Description and Corrective Actions:

Environmental Standards:

IMMEDIATELY: Contacted the ODW and re-sampled original location for bacteria, turbidity, free/total chlorine, and temperature. Monitoring was terminated after two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

Test Results: See attached

Reference No: Job 2562

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Sample Name	Sample Number	Date Sampled	E Coli (MPNU/100mL)	Total Coliform (MPNU/100mL)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity-field (ntu)	Temperature (°C)	Time Sampled (hrs)
NW08	815339	1/20/2026	0	3	1.01	1.24	0.23	3.9	11:17
NW08_Resample 1	816184	1/21/2026	0	0	1.12	1.39	0.18	3.9	15:50
NW08_Resample 2	816185	1/22/2026	0	0	1.24	1.42	0.21	3.4	14:57

Notes/Comments:

1. All microbiological tests performed by contract laboratory.
2. ol - autosampler or process offline
3. na - not applicable or not analyzed