



Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

August 7, 2026

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-11-2026-WS

Reported to ODW: August 1, 2026

Reported by: Mike Szmon, Manager of Water Services

Approved by: Zeljko Bodioga, Field Services Engineer

Incident Date: July 31, 2026

Incident Location: Winnipeg 3-Dist (WM Repair)

Incident Type:

Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

Description of Event and Corrective Actions:

Contacted the ODW and flushed the isolated area. Re-sampled original location and tested for bacteria, turbidity, and free chlorine. until two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

Test Results: See attached

Reference No: N/A

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Sample Name	Work Order Number	Date Sampled	E Coli (MPN/100mL)	Total Coliform (MPN/100mL)	Free Chlorine (mg/L)	Turbidity-field (ntu)	Time Sampled (hrs)
Hydrant -24 Lake Lawn Dr	2608211	7/31/2026	<1	1	0.34	3.68	14:34
Hydrant -24 Lake Lawn Dr_Resample 1	2608211	8/1/2026	<1	<1	0.39	2.42	16:27
Hydrant -24 Lake Lawn Dr_Resample 2	2608211	8/2/2026	<1	<1	0.39	1.34	15:10

Notes/Comments:

1. All microbiological tests performed by contract laboratory.
2. ol - autosampler or process offline
3. na - not applicable or not analyzed