



Kale Black, Sr. Drinking Water Officer  
Office of Drinking Water, Manitoba Sustainable Development  
309 – 25 Tupper Street North  
Portage La Prairie, MB R1N 3K1

May 7, 2026

**RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00**

**Incident No:** CAR-04-2026-WTP (F2)

**Reported to ODW:** May 7, 2026

**Reported by:** Dan Merredew, Water Treatment Operations Supervisor

**Approved by:** Dan Merredew, Water Treatment Operations Supervisor

**Incident Date:** April 26 -27, 2026

**Incident Location:** Winnipeg 2-Treated (WTP)

**Incident Type:**

Water Quality Monitoring (PWS-09-412-03 Clause 5.1)

**Description of Corrective Actions:**

From 09:52 on April 26 until 12:56 on April 27, 2026 the WTP's SCADA historian was not storing data from Filter 2. The issue was not identified at the time it occurred because real time data was observed by Operations.

Neither water quality nor safety were impacted by this event. All other treatment barriers including UV and chlorination remained online without issue during this event. All other filter performance was normal during this time frame.

**Reference No:** n/a

**EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING**

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports