



Kale Black, Sr. Drinking Water Officer  
Office of Drinking Water, Manitoba Sustainable Development  
309 – 25 Tupper Street North  
Portage La Prairie, MB R1N 3K1

May 7, 2026

**RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00**

**Incident No:** CAR-05-2026-WTP (UV400)

**Reported to ODW:** May 7, 2026

**Reported by:** Dan Merredew, Water Treatment Operations Supervisor

**Approved by:** Dan Merredew, Water Treatment Operations Supervisor

**Incident Date:** April 20-23, 2026

**Incident Location:** Winnipeg 2-Treated (WTP)

**Incident Type:**

Water Quality Monitoring (PWS-09-412-03 Clause 5.1)

**Description of Corrective Actions:**

From 09:08 on April 20 until 13:07 on April 23, 2026 the WTP's SCADA historian was not storing the UV dose for Reactor 400. During this time frame the Reactor was recording its flows and UV banks in operation but dose was not historized.

Neither water quality nor safety were impacted by this event. All other treatment barriers remained online without issue during this event. All filter performance was normal during this time frame.

**Reference No:** n/a

**EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING**

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports