

Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

June 5, 2026

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-06-2026-ESD

Reported to ODW: June 5, 2026

Reported by: Nancy Crawford, Regulatory Reporting Branch Head

Approved by: Courtney Diduck, Laboratory Service Branch Head

Incident Date: May 24 – 30, 2026

Incident Location: Winnipeg 2-Treated (WTP)

Incident Type: Water Quality Monitoring (PWS-09-412-03 Clause 5.1)

Description of Event and Corrective Actions:

Environmental Standards did not obtain the required number of confirmatory grab samples for Filter 5 effluent for the week of May 24-30, 2026. The filter was taken offline for planned maintenance on May 25 at 14:03 and has remained offline. A sample was not taken on May 24, prior to the planned maintenance. Environmental Standards and Water Services reviewed monitoring requirements and maintenance procedures with staff to ensure that a grab sample is taken prior to and immediately following filter maintenance activities.

Test Results: See monthly report

Reference No: n/a

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports