

Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

July 7, 2026

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-07-2026-ESD

Reported to ODW: July 7, 2026

Reported by: Nancy Crawford, Regulatory Reporting Branch Head

Approved by: Courtney Diduck, Laboratory Service Branch Head

Incident Date: May 31 – June 6, 2026

Incident Location: Winnipeg 2-Treated (WTP)

Incident Type: Water Quality Monitoring (PWS-09-412-03 Clause 5.1)

Description of Event and Corrective Actions:

Environmental Standards did not obtain the required number of confirmatory grab samples for Filter 5 effluent for the week of May 31 – June 6, 2026. The filter was taken offline for planned maintenance on May 25 and returned to service on June 5 at 13:52. A sample was not taken as per the Clause 5.1 on June 6. Environmental Standards reviewed the monitoring requirements with staff to ensure that the required number of confirmatory grab samples per week are taken, including in weeks with planned or unplanned filter maintenance activities.

Test Results: See monthly report

Reference No: n/a

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports