

Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

July 7, 2026

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-08-2026-ESD

Reported to ODW: June 16, 2026

Reported by: Courtney Diduck, Laboratory Services Branch Head

Approved by: Courtney Diduck, Laboratory Services Branch Head

Incident Date: June 15, 2026

Incident Location: Winnipeg 3-Dist (SE02)

Incident Type: Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

Description and Corrective Actions:

Environmental Standards:

IMMEDIATELY: Contacted the ODW and re-sampled original location for bacteria, turbidity, free/total chlorine, and temperature. Monitoring was terminated after two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

Test Results: See attached

Reference No: Job 2691

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Sample Name	Sample Number	Date Sampled	E Coli (MPNU/100mL)	Total Coliform (MPNU/100mL)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity-field (ntu)	Temperature (°C)	Time Sampled (hrs)
SE02	850698	6/15/2026	<1	1	0.91	1.15	0.17	17.0	11:08
SE02_Resample 1	852193	6/16/2026	<1	<1	0.99	1.26	na	17.0	15:23
SE02_Resample 1 (Duplicate)	852194	6/16/2026	<1	<1	1.00	1.27	na	17.0	15:23
SE02_Resample 2	852195	6/17/2026	<1	<1	1.05	1.28	0.17	17.4	14:59
SE02_Resample 2 (Duplicate)	852196	6/17/2026	<1	<1	1.02	1.25	0.16	17.4	15:04

Notes/Comments:

1. All microbiological tests performed by contract laboratory.
2. ol - autosampler or process offline
3. na - not applicable or not analyzed