



Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

August 7, 2026

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-09-2026-ESD

Reported to ODW: July 9, 2026

Reported by: Courtney Diduck, Laboratory Services Branch Head

Approved by: Courtney Diduck, Laboratory Services Branch Head

Incident Date: July 8, 2026

Incident Location: Winnipeg 3-Dist_WMCP

Incident Type:

Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

Description of Event and Corrective Actions:

Environmental Standards:

IMMEDIATELY: Contacted the ODW and Water Services.

Water Services:

Re-flushed the affected sequence, and re-sampled original location for bacteria, turbidity, free and total chlorine and temperature. Monitoring and flushing was terminated after two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

Test Results: See attached

Reference No: Job 2750

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Sample Name	Sample Number	Date Sampled	E Coli (MPN/100mL)	Total Coliform (MPN/100mL)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity-field (ntu)	Temperature (°C)	Time Sampled (hrs)
Hydrant Post Flush 4 (Sequence 352)	858043	8-Jul-26	<1	1	0.97	1.08	0.61	18.0	12:16
Hydrant Post Flush 4 Resample 1	858662	9-Jul-26	<1	<1	0.92	1.12	0.63	16.6	14:44
Hydrant Post Flush 4 Resample 1 (Duplicate)	858675	9-Jul-26	<1	<1	0.89	1.08	1.02	16.5	16:45
Hydrant Post Flush 4 Resample 2	858689	10-Jul-26	<1	<1	0.85	1.13	1.63	17.9	14:54
Hydrant Post Flush 4 Resample 2 (Duplicate)	858690	10-Jul-26	<1	<1	0.83	1.17	0.98	18.0	14:55

Notes/Comments:

1. All microbiological tests performed by contract laboratory.
2. ol - autosampler or process offline
3. na - not applicable or not analyzed