



## Water and Waste Department • Service des eaux et des déchets

---

May 6, 2016

Melanie Betsill  
Office of Drinking Water  
Manitoba Conservation and Water Stewardship  
1007 Century Street  
Winnipeg, Manitoba R3H 0W4

Our File: 040-18-18-55-00

Dear Ms. Betsill:

**RE: APRIL 2016 WATER QUALITY COMPLIANCE  
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for April 2016. There are no corrective action reports to be submitted for April 2016.

The April on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the effluent from the filters met the licence requirements.

The April on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The April UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at [rgrosselle@winnipeg.ca](mailto:rgrosselle@winnipeg.ca).

Yours sincerely,

*Original signed by:*

R. Grosselle  
Manager of Environmental Standards  
Attachments

c:(e-mail)

Dr. L. Richards, Winnipeg Regional Health Authority  
Dr. H. Chang, Winnipeg Regional Health Authority  
Dr. S. Roberecki, Manitoba Health, Healthy Living and Seniors  
M. L. Geer, CPA, CA  
G. Patton, P.Eng.  
T. Shanks, P.Eng.  
M. Szmon, P.Eng.  
C. Diduck

N:\Compliance Reporting\Submittal Letters\2016\ODW - Monthly Compliance Letters\ODW Letter 2016-04.doc



**CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
WATER SERVICES

Water System Code: 252.00  
Licence Number: PWS-09-412-01

**WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT**

April 2016 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/04/2016	0.63	0.01	0.06	0.02	0.10	0.04	0.11	0.02	0.09	0.01	0.06	0.03	0.04	0.02	0.05	0.00	0.04	
2/04/2016	0.63	0.02	0.09	0.04	0.11	0.04	0.16	0.05	0.07	0.02	0.08	0.05	0.12	0.03	0.05	0.01	0.04	
3/04/2016	0.62	0.02	0.04	0.03	0.11	0.07	0.12	0.04	0.14	0.01	0.03	0.04	0.15	0.04	0.12	0.01	0.07	
4/04/2016	0.61	0.02	0.08	0.04	0.06	0.05	0.15	0.04	0.15	0.03	0.08	0.04	0.07	0.03	0.12	0.00	0.07	
5/04/2016	0.60	0.02	0.08	0.03	0.11	0.04	0.15	0.05	0.13	0.02	0.08	0.06	0.14	0.03	0.05	0.01	0.05	
6/04/2016	0.60	0.02	0.04	0.02	0.10	0.07	0.11	0.04	0.14	0.01	0.03	0.04	0.13	0.05	0.12	0.01	0.06	
7/04/2016	0.60	0.02	0.08	0.04	0.07	0.05	0.15	0.03	0.12	0.02	0.07	0.04	0.06	0.04	0.13	0.00	0.01	
8/04/2016	0.60	0.02	0.08	0.03	0.10	0.03	0.15	0.05	0.06	0.01	0.06	0.04	0.12	0.04	0.07	0.01	0.07	
9/04/2016	0.59	0.02	0.04	0.02	0.11	0.07	0.13	0.04	0.13	0.01	0.02	0.03	0.12	0.05	0.13	0.01	0.06	
10/04/2016	0.58	0.02	0.09	0.05	0.10	0.05	0.16	0.03	0.05	0.02	0.08	0.04	0.06	0.04	0.13	0.01	0.01	
11/04/2016	0.58	0.01	0.03	0.03	0.11	0.05	0.09	0.05	0.13	0.01	0.06	0.03	0.11	0.06	0.08	0.01	0.06	
12/04/2016	0.60	0.03	0.08	0.03	0.05	0.06	0.15	0.03	0.12	0.01	0.04	0.03	0.05	0.04	0.13	0.01	0.06	
13/04/2016	0.60	0.02	0.08	0.04	0.11	0.04	0.16	0.04	0.05	0.02	0.07	0.05	0.12	0.04	0.06	0.01	0.03	
14/04/2016	0.60	0.02	0.04	0.03	0.11	0.07	0.10	0.04	0.13	0.01	0.02	0.03	0.15	0.06	0.28	0.01	0.06	
15/04/2016	0.61	0.02	0.08	0.04	0.06	0.05	0.15	0.03	0.12	0.02	0.08	0.03	0.05	0.04	0.13	0.00	0.01	
16/04/2016	0.61	0.01	0.07	0.03	0.10	0.04	0.07	0.04	0.06	0.01	0.05	0.04	0.12	0.05	0.07	0.01	0.07	
17/04/2016	0.63	0.02	0.04	0.01	0.04	0.04	0.14	0.01	0.10	0.01	0.02	0.02	0.07	0.03	0.11	0.00	0.03	
18/04/2016	0.62	0.01	0.04	0.02	0.05	0.02	0.10	0.01	0.08	0.00	0.02	0.02	0.04	0.05	0.21	0.01	0.01	
19/04/2016	0.62	0.01	0.03	0.02	0.07	0.03	0.06	0.02	0.06	0.01	0.04	0.02	0.09	0.03	0.06	0.01	0.04	
20/04/2016	0.65	0.01	0.03	0.01	0.02	0.03	0.13	0.02	0.07	0.00	0.01	0.02	0.09	0.05	0.11	0.00	0.02	
21/04/2016	0.69	0.01	0.04	0.01	0.06	0.02	0.10	0.01	0.03	0.00	0.03	0.03	0.05	0.04	0.10	0.01	0.01	
22/04/2016	0.69	0.01	0.01	0.01	0.03	0.02	0.04	0.02	0.05	0.00	0.03	0.02	0.07	0.03	0.05	0.00	0.01	
23/04/2016	0.68	0.01	0.02	0.00	0.01	0.02	0.09	0.01	0.05	0.01	0.02	0.01	0.03	0.06	0.09	0.00	0.01	
24/04/2016	0.70	0.01	0.02	0.01	0.04	0.01	0.03	0.01	0.02	0.00	0.04	0.03	0.08	0.04	0.10	0.01	0.01	
25/04/2016	0.71	0.01	0.01	0.01	0.05	0.04	0.10	0.01	0.06	0.00	0.01	0.02	0.09	0.06	0.07	0.00	0.02	
26/04/2016	0.73	0.01	0.03	0.01	0.02	0.03	0.11	0.01	0.07	0.01	0.04	0.03	0.05	0.05	0.12	0.00	0.01	
27/04/2016	0.73	0.01	0.03	0.01	0.06	0.03	0.07	0.02	0.04	0.01	0.06	0.04	0.10	0.04	0.07	0.01	0.03	
28/04/2016	0.74	0.01	0.04	0.01	0.06	0.03	0.11	0.02	0.07	0.01	0.02	0.03	0.11	0.01	0.02	0.01	0.06	
29/04/2016	0.74	0.01	0.07	0.02	0.03	0.02	0.11	0.01	0.07	0.02	0.06	0.04	0.06	0.01	0.07	0.00	0.01	
30/04/2016	0.73	0.01	0.01	0.01	0.06	0.03	0.04	0.02	0.04	0.01	0.05	0.04	0.11	0.01	0.07	0.01	0.07	

Total Number of Measurements Taken, A: 13297  
Turbidity Standard for Monitoring Location (NTU): 0.30  
Number of Measurements Meeting Standard, B: 13297  
Compliance with Turbidity Standard, C = B/A X 100%: 100%

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2016\04-April

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

**WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT**

Water System Code: 252.00 Licence No. PWS-09-412-01	Turbidity (NTU)																		
	Date	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
		Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
	01-Apr-2016	0.50	0.61	0.06	<0.02	0.05	<0.02	0.12	0.05	0.06	<0.02	0.06	<0.02	0.06	<0.02	OL	OL	<0.05	<0.02
	02-Apr-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	03-Apr-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	04-Apr-2016	0.54	0.60	0.13	0.03	0.11	0.05	0.17	0.09	0.11	0.03	0.12	0.02	0.13	0.04	0.15	0.08	0.12	<0.02
	05-Apr-2016	0.55	0.60	OL	OL	0.16	0.09	0.11	0.05	0.11	0.03	0.15	0.06	0.12	0.06	0.09	0.03	0.09	0.02
	06-Apr-2016	0.51	0.57	0.09	<0.02	0.08	0.03	0.14	0.07	0.16	0.07	0.09	<0.02	OL	OL	0.12	0.05	0.12	0.04
	07-Apr-2016	0.50	0.58	0.17	0.04	0.14	0.05	0.18	0.10	0.11	0.02	0.10	<0.02	0.11	0.04	OL	OL	0.09	<0.02
	08-Apr-2016	0.51	0.60	0.09	<0.02	0.12	0.06	0.12	0.05	0.12	0.03	0.11	0.03	0.13	0.06	0.10	0.04	0.09	0.02
	09-Apr-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	10-Apr-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	11-Apr-2016	0.50	0.58	0.10	<0.02	0.16	0.09	0.13	0.05	0.14	0.04	0.09	<0.02	0.12	0.05	0.12	0.05	0.11	0.03
	12-Apr-2016	0.63	0.58	0.10	0.02	0.11	0.04	0.16	0.09	OL	OL	0.09	<0.02	0.09	0.03	OL	OL	0.08	<0.02
	13-Apr-2016	0.48	0.58	OL	OL	0.14	0.07	0.13	0.05	0.12	0.03	0.13	0.03	0.12	0.04	0.09	0.05	0.09	0.02
	14-Apr-2016	0.48	0.58	0.10	<0.02	0.09	0.04	0.14	0.07	0.10	0.06	0.15	<0.02	OL	OL	0.10	0.07	0.12	0.03
	15-Apr-2016	0.53	0.60	0.14	0.04	0.10	0.04	0.17	0.10	0.11	0.02	0.11	0.02	0.11	0.03	OL	OL	0.08	<0.02
	16-Apr-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	17-Apr-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	18-Apr-2016	0.51	0.62	0.09	<0.02	0.09	0.02	0.08	0.02	0.08	<0.02	0.10	<0.02	0.07	<0.02	0.09	0.06	0.09	<0.02
	19-Apr-2016	0.44	0.63	0.07	<0.02	0.13	0.06	0.10	0.04	0.10	<0.02	0.08	<0.02	0.09	0.03	0.07	0.04	0.08	0.02
	20-Apr-2016	0.57	0.62	0.08	<0.02	0.08	0.02	0.16	0.09	0.13	0.04	0.08	<0.02	0.08	<0.02	0.09	0.06	OL	OL
	21-Apr-2016	0.55	0.69	OL	OL	0.08	0.02	0.06	0.02	0.06	<0.02	0.09	<0.02	0.08	0.02	0.09	0.06	0.06	<0.02
	22-Apr-2016	0.60	0.70	0.05	<0.02	OL	OL	0.08	0.02	0.08	<0.02	0.07	<0.02	0.08	0.03	0.06	0.04	0.07	<0.02
	23-Apr-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	24-Apr-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	25-Apr-2016	0.50	0.69	0.08	<0.02	0.06	<0.02	0.11	0.04	0.10	<0.02	0.07	<0.02	OL	OL	0.09	0.06	0.10	<0.02
	26-Apr-2016	0.56	0.70	0.11	<0.02	0.06	<0.02	OL	OL	0.07	<0.02	0.07	<0.02	0.07	0.02	0.08	0.07	0.09	<0.02
	27-Apr-2016	0.64	0.72	0.06	<0.02	0.07	0.02	0.08	0.03	0.07	<0.02	0.11	0.04	0.13	0.05	0.09	0.06	0.09	<0.02
	28-Apr-2016	0.56	0.74	0.09	<0.02	0.06	0.02	0.13	0.05	OL	OL	0.09	<0.02	0.09	0.03	0.09	<0.02	OL	OL
	29-Apr-2016	0.63	0.74	0.08	<0.02	0.07	0.02	0.07	0.02	0.07	<0.02	0.10	0.02	0.09	0.04	0.13	0.03	0.08	<0.02
	30-Apr-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
<b>Total number of measurements taken, A:</b>				18		20		20		19		21		18		17		18	
<b>Turbidity Standard for Monitoring Location (NTU):</b>				0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
<b>Number of measurements meeting standard, B:</b>				18		20		20		19		21		18		17		18	
<b>Compliance with Turbidity Standard, C= B/A X 100%:</b>				100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: H.Demchenko

Approved in LIMS By: C.Diduck

Date Approved: 6-May-16



City of Winnipeg

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT  
Deacon Booster Pumping Station

Water System Code: **252.00**  
Licence Number: **PWS-09-412-01**  
Report Created: 01 May 2016

Report Period: April 2016

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
1/04/2016	0.95	0.80	1.07	0.91
2/04/2016	0.88	0.78	0.95	0.88
3/04/2016	0.95	0.93	0.95	0.94
4/04/2016	1.00	0.93	0.98	0.94
5/04/2016	1.14	0.96	1.03	0.98
6/04/2016	1.25	1.03	1.05	1.00
7/04/2016	1.04	0.99	1.03	0.94
8/04/2016	1.11	1.00	1.03	1.00
9/04/2016	1.15	1.03	0.99	0.89
10/04/2016	1.14	1.09	1.02	0.99
11/04/2016	1.16	1.11	1.03	0.99
12/04/2016	1.13	1.10	1.00	0.98
13/04/2016	1.16	1.11	1.01	0.99
14/04/2016	1.16	1.08	1.02	0.92
15/04/2016	1.11	1.05	1.02	0.97
16/04/2016	1.16	1.12	1.00	0.99
17/04/2016	1.18	1.12	1.13	0.99
18/04/2016	1.09	1.05	1.16	1.10
19/04/2016	1.08	1.03	1.08	1.03
20/04/2016	1.07	1.00	1.08	1.05
21/04/2016	1.06	1.03	1.12	1.09
22/04/2016	1.07	1.01	1.10	1.07
23/04/2016	1.09	1.05	1.11	1.08
24/04/2016	1.08	1.03	1.11	1.07
25/04/2016	1.03	0.96	1.05	0.98
26/04/2016	1.04	0.94	0.99	0.94
27/04/2016	0.99	0.89	1.06	0.83
28/04/2016	0.90	0.79	0.95	0.86
29/04/2016	0.93	0.80	1.01	0.92
30/04/2016	0.98	0.86	1.03	0.93

Total Number of Measurements, A: 20853 20873  
Minimum Free Chlorine Standard: 0.50 0.50  
Number of Measurements Meeting Standard, B: 20853 20873  
COMPLIANCE, C = B/A X 100%: 100 100

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2016\04-April

Submitted By (Print): D.MerredewSignature: Original signed by D.Merredew



CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

**WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT**

Water System Code: 252.00 Licence No. PWS-09-412-01	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
	Date	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	
		Analyser	Grab	Grab	Analyser	Grab
01-Apr-2016		1.05	0.95	1.14	1.22	0.99
02-Apr-2016		NS	NS	NS	NS	NS
03-Apr-2016		NS	NS	NS	NS	NS
04-Apr-2016		0.99	1.04	1.15	0.99	1.04
05-Apr-2016		1.00	1.03	1.17	1.02	1.02
06-Apr-2016		1.24	1.15	1.44	1.05	1.05
07-Apr-2016		1.08	1.04	1.24	1.08	1.01
08-Apr-2016		1.09	1.15	1.30	1.09	1.14
09-Apr-2016		NS	NS	NS	NS	NS
10-Apr-2016		NS	NS	NS	NS	NS
11-Apr-2016		1.13	1.20	1.39	1.02	1.06
12-Apr-2016		1.13	1.21	1.35	1.00	1.00
13-Apr-2016		1.14	1.24	1.37	1.01	1.07
14-Apr-2016		1.14	1.25	1.37	0.93	1.03
15-Apr-2016		1.09	1.17	1.33	1.06	1.03
16-Apr-2016		NS	NS	NS	NS	NS
17-Apr-2016		NS	NS	NS	NS	NS
18-Apr-2016		1.13	1.17	1.36	1.25	1.21
19-Apr-2016		1.11	1.19	1.29	1.09	1.19
20-Apr-2016		1.11	1.16	1.28	1.07	1.15
21-Apr-2016		1.08	1.18	1.32	1.12	1.19
22-Apr-2016		1.02	1.05	1.26	1.10	1.13
23-Apr-2016		NS	NS	NS	NS	NS
24-Apr-2016		NS	NS	NS	NS	NS
25-Apr-2016		1.04	1.08	1.22	1.10	1.14
26-Apr-2016		1.13	1.06	1.16	0.97	1.07
27-Apr-2016		1.04	1.07	1.21	1.25	1.06
28-Apr-2016		0.88	0.87	1.01	0.89	0.89
29-Apr-2016		0.90	0.97	1.10	0.96	0.98
30-Apr-2016		NS	NS	NS	NS	NS
<b>Total number of measurements taken, A:</b>		21			21	
<b>Chlorine Standard for Monitoring Location (mg/L):</b>		0.50			0.50	
<b>Number of measurements meeting standard, B:</b>		21			21	
<b>Compliance with Chlorine Standard, C= B/A X 100%:</b>		100%			100%	

NS: No Sample    NA: Not Analyzed    OL: Off-Line

Comments:

Report Compiled By: \_\_\_\_\_ H.Demchenko

Approved in LIMS By: \_\_\_\_\_ C.Diduck



**CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
WATER SERVICES

Water System Code: 252.00  
Licence Number: PWS-09-412-01

WATER TREATMENT PLANT UV REPORT

Report Period: April 2016

Report Created: Sunday, May 01, 2016

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose	
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]					
	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total			
01/04/2016	96.18	0.00	0.00	0.00	0.00	0.00	0.00	82.75	82.75	0.00	0.00	10.72	10.72	0.00	0.00	56.25	56.25	0.00	0.00	25.10	25.10	0.00	0.00	23.45	23.45	0.00	0.00	198.27	198.27	100.00	
02/04/2016	96.17	0.00	0.00	0.00	0.00	0.00	0.00	79.01	79.01	0.00	0.00	45.09	45.09	0.03	0.03	4.24	4.30	0.00	0.00	27.85	27.85	0.03	0.03	33.32	33.39	0.06	0.06	189.50	189.63	99.93	
03/04/2016	96.25	0.00	0.00	0.00	0.00	0.00	0.00	79.11	79.11	0.00	0.00	49.17	49.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	190.83	190.83	100.00	
04/04/2016	96.22	0.00	0.16	32.53	32.69	0.00	0.00	45.31	45.31	0.00	0.00	50.54	50.54	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	192.82	192.98	99.92	
05/04/2016	96.24	0.00	0.16	56.03	56.19	0.00	0.00	24.27	24.27	0.03	0.03	29.51	29.57	0.00	0.00	0.00	0.00	0.00	0.00	15.16	15.16	0.00	0.00	65.70	65.70	0.03	0.19	190.66	190.88	99.89	
06/04/2016	96.41	0.00	0.00	56.52	56.52	0.00	0.00	28.35	28.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37.44	37.44	0.00	0.00	67.44	67.44	0.00	0.00	189.74	189.74	100.00			
07/04/2016	96.45	0.00	0.00	50.35	50.35	0.00	0.00	26.86	26.86	0.00	0.00	0.00	0.00	0.00	0.00	30.20	30.20	0.00	0.00	60.90	60.90	0.00	0.00	21.71	21.71	0.00	0.00	190.03	190.03	100.00	
08/04/2016	96.41	0.00	0.00	72.90	72.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	44.21	44.21	0.00	0.00	35.78	35.78	0.00	0.00	35.74	35.74	0.00	0.00	188.63	188.64	100.00	
09/04/2016	96.51	0.00	0.00	70.91	70.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	42.44	42.44	0.00	0.00	0.00	0.00	0.00	0.00	67.09	67.09	0.00	0.00	180.43	180.43	100.00	
10/04/2016	96.50	0.00	0.00	70.51	70.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	42.64	42.64	0.00	0.00	0.00	0.00	0.00	0.00	66.81	66.81	0.00	0.00	179.96	179.96	100.00	
11/04/2016	96.42	0.00	0.00	70.42	70.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	42.72	42.72	0.00	0.00	0.00	0.00	0.05	0.05	66.82	66.86	0.00	0.00	179.95	179.99	99.97	
12/04/2016	96.51	0.00	0.00	70.60	70.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	43.22	43.22	0.00	0.00	0.00	0.00	0.00	0.00	66.18	66.18	0.00	0.00	180.00	180.00	100.00	
13/04/2016	96.53	0.00	0.00	72.49	72.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	49.47	49.47	0.00	0.00	0.00	0.00	0.00	0.00	58.02	58.02	0.00	0.00	179.98	179.98	100.00	
14/04/2016	96.47	0.00	0.00	74.35	74.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	55.70	55.70	0.00	0.00	0.00	0.00	0.00	0.00	50.00	50.00	0.00	0.00	180.05	180.05	100.00	
15/04/2016	96.58	0.00	0.00	75.45	75.45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.24	59.24	0.00	0.00	0.00	0.00	0.00	0.00	46.28	46.28	0.00	0.00	180.96	180.96	100.00	
16/04/2016	96.71	0.00	0.00	77.13	77.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	63.60	63.60	0.00	0.00	0.00	0.00	0.00	0.00	40.30	40.30	0.00	0.00	181.03	181.03	100.00	
17/04/2016	97.20	0.00	0.00	74.63	74.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	55.86	55.86	0.00	0.00	31.95	31.95	0.00	0.00	18.53	18.53	0.00	0.00	180.98	180.98	100.00	
18/04/2016	97.19	0.00	0.00	69.56	69.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	42.50	42.50	0.00	0.00	67.10	67.10	0.00	0.00	0.00	0.00	0.00	0.00	179.16	179.16	100.00	
19/04/2016	97.25	0.00	0.00	69.66	69.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	42.49	42.49	0.00	0.00	65.50	65.50	0.00	0.00	0.00	0.00	0.00	0.00	177.66	177.66	100.00	
20/04/2016	97.32	0.00	0.00	69.86	69.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.86	21.86	0.00	0.00	67.57	67.57	0.00	0.00	0.00	0.00	0.00	0.00	180.99	180.99	100.00	
21/04/2016	97.77	0.00	0.00	69.21	69.21	0.00	0.00	0.00	0.00	0.00	0.00	44.13	44.13	0.00	0.00	0.00	0.00	68.43	68.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	181.77	181.77	100.00	
22/04/2016	97.85	0.00	0.00	69.74	69.74	0.00	0.00	0.00	0.00	0.00	0.00	44.72	44.72	0.00	0.00	0.00	0.00	69.57	69.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	184.03	184.03	100.00	
23/04/2016	97.85	0.00	0.00	69.85	69.85	0.00	0.00	0.00	0.00	0.00	0.00	44.70	44.70	0.00	0.00	0.00	0.00	69.45	69.45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	184.00	184.00	100.00	
24/04/2016	97.71	0.00	0.00	69.90	69.90	0.00	0.00	0.00	0.00	0.00	0.00	44.73	44.73	0.00	0.00	0.00	0.00	69.39	69.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	184.02	184.02	100.00	
25/04/2016	97.63	0.00	0.00	27.45	27.45	0.00	0.05	45.98	46.04	0.00	0.00	20.16	20.16	0.00	0.00	23.95	23.95	0.00	0.00	68.29	68.29	0.00	0.00	0.00	0.00	0.00	0.00	0.05	185.83	185.88	99.97
26/04/2016	97.61	0.00	0.00	0.00	0.00	0.00	0.00	0.11	76.46	76.46	0.00	0.00	0.00	0.00	0.00	0.00	44.05	44.05	0.00	0.00	68.87	68.87	0.00	0.00	0.00	0.00	0.11	189.37	189.48	99.94	
27/04/2016	97.56	0.00	0.00	0.00	0.00	0.00	0.05	76.71	76.76	0.00	0.00	0.00	0.00	0.00	0.00	43.99	43.99	0.00	0.00	69.24	69.24	0.00	0.00	0.00	0.00	0.05	189.94	189.99	99.97		
28/04/2016	97.49	0.00	0.00	0.00	0.00	0.00	0.05	76.68	76.73	0.00	0.00	0.00	0.00	0.00	0.00	43.96	43.96	0.00	0.00	69.32	69.32	0.00	0.00	0.00	0.00	0.05	189.95	190.00	99.97		
29/04/2016	97.55	0.00	0.00	0.00	0.00	0.00	0.16	76.52	76.68	0.00	0.00	0.00	0.00	0.00	0.00	43.92	43.92	0.00	0.00	69.39	69.39	0.00	0.00	0.00	0.00	0.16	189.84	189.99	99.92		
30/04/2016	97.53	0.00	0.00	0.00	0.00	0.00	0.05	76.68	76.74	0.00	0.00	0.00	0.00	0.00	0.00	43.93	43.93	0.00	0.00	69.32	69.32	0.00	0.00	0.00	0.00	0.05	189.94	189.99	99.97		
		0.00	0.32	1440.04	1440.36	0.00	0.48	794.69	795.17	0.03	0.03	405.16	405.22	0.03	0.03	940.42	940.48	0.00	0.00	1125.62	1125.62	0.04	0.08	854.38	854.49	0.09	0.94	5560.31	5561.34		

Water Volume [%]:

Untreated: 0.00 %

Below Dose: 0.02 %

To Dose: 99.98 %

Submitted By (Print): D.Merredew

Signature: Original