



Water and Waste Eaux et déchets

Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Conservation and Climate
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

October 7, 2024

RE: SEPTEMBER 2024 WATER QUALITY COMPLIANCE SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for September 2024.

The on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The maximum turbidity was greater than 0.30 NTU on Filter 6 on September 5 and Filter 5 on September 26; the elevated turbidities occurred for less than 12 consecutive hours. The turbidity results for the filter effluent met the licence requirements.

The on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The UV summary reports include results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

R. Grosselle
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)
Dr. H. Chang, Winnipeg Regional Health Authority (email)
Dr. T. Hilderman, Manitoba Health and Seniors Care (email)
T. Shanks, M. Eng., P. Eng. (email)
M. Szmon, P. Eng. (email)
H. Buhler, P. Eng. (email)
C. Wiebe, P. Eng. (email)
C. Diduck (email)



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-02-AA

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

September 2024	Turbidity (NTU)																	
Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/09/2024	4.98	0.08	0.12	0.05	0.08	0.09	0.16	0.05	0.10	0.09	0.14	0.07	0.12	0.02	0.06	0.07	0.10	
2/09/2024	5.00	0.09	0.11	0.06	0.10	0.11	0.19	0.05	0.10	0.10	0.14	0.06	0.16	0.02	0.05	0.07	0.11	
3/09/2024	4.93	0.09	0.13	0.05	0.11	0.12	0.24	0.07	0.10	0.08	0.15	0.06	0.14	0.02	0.03	0.07	0.13	
4/09/2024	4.04	0.06	0.13	0.05	0.10	0.08	0.19	0.07	0.11	0.06	0.10	0.04	0.09	0.03	0.05	0.05	0.15	
5/09/2024	4.78	0.07	0.11	0.05	0.12	0.06	0.15	0.07	0.12	0.07	0.11	0.05	0.36	0.04	0.08	0.03	0.07	
6/09/2024	3.69	0.07	0.13	0.06	0.10	0.06	0.14	0.06	0.12	0.08	0.11	0.04	0.09	0.03	0.07	0.03	0.08	
7/09/2024	4.73	0.09	0.26	0.06	0.12	0.06	0.14	0.07	0.09	0.08	0.13	0.04	0.09	0.04	0.08	0.04	0.09	
8/09/2024	4.94	0.07	0.12	0.05	0.11	0.06	0.09	0.07	0.11	0.06	0.11	0.04	0.08	0.04	0.08	0.04	0.08	
9/09/2024	3.60	0.06	0.10	0.04	0.10	0.06	0.12	0.06	0.10	0.05	0.08	0.04	0.07	0.03	0.08	0.03	0.07	
10/09/2024	3.92	0.07	0.12	0.06	0.11	0.07	0.12	0.07	0.17	0.04	0.08	0.03	0.07	0.03	0.06	0.04	0.07	
11/09/2024	4.55	0.08	0.11	0.06	0.11	0.07	0.16	0.07	0.12	0.07	0.10	0.04	0.09	0.03	0.07	0.05	0.10	
12/09/2024	4.97	0.07	0.11	0.05	0.11	0.06	0.14	0.07	0.25	0.04	0.09	0.04	0.08	0.03	0.06	0.05	0.21	
13/09/2024	5.00	0.07	0.13	0.06	0.11	0.10	0.16	0.08	0.13	0.04	0.07	0.04	0.25	0.04	0.08	0.05	0.10	
14/09/2024	4.98	0.07	0.13	0.05	0.22	0.10	0.17	0.07	0.12	0.04	0.08	0.04	0.07	0.03	0.07	0.07	0.09	
15/09/2024	4.53	0.06	0.13	0.07	0.12	0.11	0.17	0.06	0.11	0.03	0.06	0.04	0.08	0.03	0.06	0.07	0.12	
16/09/2024	4.68	0.08	0.10	0.06	0.20	0.14	0.24	0.06	0.09	0.05	0.09	0.05	0.08	0.03	0.07	0.09	0.13	
17/09/2024	4.79	0.07	0.11	0.06	0.14	0.17	0.26	0.07	0.11	0.04	0.08	0.04	0.07	0.07	0.05	0.10	0.15	
18/09/2024	4.31	0.07	0.10	0.06	0.13	0.04	0.06	0.07	0.12	0.04	0.08	0.03	0.07	0.04	0.06	0.10	0.19	
19/09/2024	4.13	0.06	0.10	0.06	0.10	0.03	0.09	0.06	0.11	0.03	0.06	0.03	0.08	0.02	0.05	0.13	0.15	
20/09/2024	4.21	0.06	0.08	0.08	0.10	0.03	0.10	0.06	0.11	0.04	0.06	0.03	0.07	0.01	0.03	0.13	0.17	
21/09/2024	4.91	0.08	0.11	0.08	0.22	0.03	0.10	0.06	0.09	0.05	0.08	0.03	0.07	0.01	0.02	0.13	0.21	
22/09/2024	4.86	0.08	0.12	0.08	0.13	0.03	0.07	0.05	0.11	0.06	0.09	0.03	0.05	0.01	0.04	0.14	0.19	
23/09/2024	5.00	0.08	0.12	0.09	0.11	0.03	0.10	0.05	0.12	0.05	0.08	0.04	0.07	0.01	0.04	0.14	0.21	
24/09/2024	4.99	0.08	0.10	0.06	0.11	0.02	0.06	0.05	0.08	0.06	0.08	0.04	0.07	0.01	0.02	0.11	0.16	
25/09/2024	4.98	0.08	0.12	0.06	0.10	0.02	0.04	0.06	0.07	0.04	0.10	0.03	0.06	0.01	0.03	0.11	0.17	
26/09/2024	4.91	0.07	0.12	0.06	0.10	0.03	0.05	0.06	0.08	0.03	0.53	0.03	0.04	0.01	0.02	0.10	0.14	
27/09/2024	5.00	0.08	0.12	0.07	0.11	0.03	0.06	0.06	0.09	0.05	0.08	0.04	0.06	0.01	0.03	0.12	0.14	
28/09/2024	4.97	0.09	0.12	0.09	0.11	0.03	0.07	0.06	0.09	0.05	0.08	0.04	0.07	0.01	0.03	0.11	0.15	
29/09/2024	4.39	0.09	0.15	0.07	0.11	0.02	0.06	0.06	0.08	0.04	0.09	0.04	0.07	0.01	0.03	0.10	0.22	
30/09/2024	3.33	0.08	0.12	0.08	0.12	0.02	0.05	0.05	0.09	0.05	0.11	0.04	0.08	0.02	0.04	0.06	0.13	

Total Number of Measurements Taken, A: 15155 15194 14540 15800 16200 15912 15200 15099
Turbidity Standard for Monitoring Location (NTU): 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3
Number of Measurements Meeting Standard, B: 15155 15194 14540 15800 16199 15911 15200 15099
Compliance with Turbidity Standard, C = B/A X 100%: 100.000% 100.000% 100.000% 100.000% 99.994% 99.994% 100.000% 100.000%

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2024\09-September

Submitted By (Print): D. Merredew

Signature: original signed by D. Merredew



Water Treatment Plant Turbidity Grab Monitoring Report
September 2024

Date	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Sep-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
02-Sep-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
03-Sep-2024	3.38	6.30	0.17	0.11	0.16	0.07	0.18	0.14	0.15	0.07	0.16	0.13	0.15	0.07	0.15	0.02	0.13	0.09
04-Sep-2024	2.53	3.54	0.18	0.09	0.15	0.07	0.17	0.08	0.16	0.08	0.11	0.09	0.13	0.07	0.14	0.02	0.13	0.09
05-Sep-2024	3.13	5.90	0.14	0.08	0.15	0.06	0.19	0.09	0.15	0.06	0.14	0.08	0.16	0.05	0.20	0.07	0.16	0.04
06-Sep-2024	2.34	2.75	0.14	0.09	0.15	0.07	0.21	0.12	0.13	0.07	0.14	0.10	0.18	0.09	0.13	0.03	0.16	0.06
07-Sep-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
08-Sep-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
09-Sep-2024	2.22	2.53	0.27	0.22	0.17	0.05	0.17	0.06	0.17	0.09	0.13	0.06	0.15	0.05	0.10	0.03	0.15	0.05
10-Sep-2024	2.11	2.72	0.13	0.09	0.14	0.07	0.20	0.11	0.13	0.07	0.12	0.05	0.13	0.05	0.13	0.04	0.13	0.05
11-Sep-2024	3.18	6.10	0.14	0.09	0.16	0.09	0.16	0.07	0.14	0.08	0.15	0.10	0.18	0.08	0.13	0.03	0.16	0.09
12-Sep-2024	3.24	6.20	0.14	0.10	0.17	0.10	0.14	0.07	0.13	0.07	0.15	0.09	0.14	0.05	0.14	0.04	0.13	0.07
13-Sep-2024	3.32	7.03	0.16	<0.02	0.13	0.07	0.17	0.10	0.17	0.11	0.11	0.04	0.13	0.05	0.14	0.04	0.14	0.07
14-Sep-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
15-Sep-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
16-Sep-2024	2.37	3.69	0.13	0.08	0.14	0.09	0.15	0.15	0.13	0.07	0.12	0.06	0.12	0.06	0.12	0.02	0.17	0.14
17-Sep-2024	2.65	5.45	0.14	0.09	0.12	0.07	0.15	0.19	0.13	0.08	0.14	0.07	0.12	0.05	0.14	0.02	0.13	0.11
18-Sep-2024	2.62	4.45	0.15	0.10	0.10	0.07	0.11	0.02	0.13	0.07	0.09	0.05	0.10	0.03	0.10	<0.02	0.12	0.11
19-Sep-2024	2.23	4.19	0.11	0.07	0.11	0.07	0.16	0.05	0.11	0.06	0.11	0.04	0.13	0.05	0.13	<0.02	0.13	0.14
20-Sep-2024	2.36	3.86	0.11	0.08	0.12	0.09	0.13	0.03	0.12	0.07	0.12	0.06	0.15	0.08	0.12	<0.02	0.14	0.16
21-Sep-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
22-Sep-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
23-Sep-2024	2.97	6.49	0.12	0.09	0.12	0.10	0.18	0.06	0.12	0.06	0.11	0.07	0.12	0.05	0.15	0.03	0.13	0.15
24-Sep-2024	2.45	5.93	0.12	0.10	0.12	0.07	0.11	0.02	0.12	0.06	0.12	0.08	0.11	0.07	0.12	<0.02	0.11	0.14
25-Sep-2024	2.09	6.05	0.11	0.10	0.12	0.09	0.13	0.03	0.11	0.06	0.11	0.08	0.10	0.04	0.10	<0.02	0.11	0.14
26-Sep-2024	2.07	14.26	0.13	0.10	0.13	0.08	0.13	0.04	0.12	0.07	0.10	0.04	0.10	0.04	0.10	<0.02	0.11	0.13
27-Sep-2024	2.80	2.46	0.10	0.11	0.10	0.08	0.14	0.05	0.08	0.08	0.10	0.08	0.09	0.06	0.10	<0.02	0.11	0.14
28-Sep-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
29-Sep-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
30-Sep-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
Total number of measurements taken, A:	19		19		19		19		19		19		19		19		19	
Turbidity Standard for Monitoring Location (NTU):	0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:	19		19		19		19		19		19		19		19		19	
Compliance with Turbidity Standard, C= B/A X 100%:	100%		100%		100%		100%		100%		100%		100%		100%		100%	

na: not analyzed nr: no result ns: no sample o/: offline im: instrument maintenance

Comments:

The raw water analyzer is cleaned daily during warm water months because it is susceptible to frequent fouling

Report Date: October 7, 2024

**City Of Winnipeg**Water and Waste Department
Water Services**WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT**
Deacon Booster Pumping StationWater System Code: **252.00**Licence Number: **PWS-09-412-02-AA**Report Created: **01 October 2024**

Report Period: September 2024

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/09/2024	1.46	1.38	1.43	1.36
02/09/2024	1.46	1.38	1.42	1.37
03/09/2024	1.42	1.31	1.40	1.30
04/09/2024	1.40	1.20	1.40	1.25
05/09/2024	1.57	1.45	1.57	1.46
06/09/2024	1.60	1.51	1.52	1.13
07/09/2024	1.62	1.52	1.61	1.55
08/09/2024	1.64	1.52	1.64	1.55
09/09/2024	1.58	1.39	1.59	1.47
10/09/2024	1.63	1.51	1.63	1.57
11/09/2024	1.64	1.54	1.67	1.57
12/09/2024	1.73	1.60	1.73	1.65
13/09/2024	1.71	1.54	1.69	1.56
14/09/2024	1.62	1.47	1.60	1.52
15/09/2024	1.65	1.53	1.62	1.56
16/09/2024	1.61	1.49	1.65	1.60
17/09/2024	1.53	1.33	1.57	1.43
18/09/2024	1.58	1.40	1.50	1.12
19/09/2024	1.51	1.39	1.52	1.43
20/09/2024	1.49	1.39	1.48	1.22
21/09/2024	1.63	1.44	1.55	1.43
22/09/2024	1.68	1.59	1.54	1.48
23/09/2024	1.76	1.63	1.62	1.36
24/09/2024	1.74	1.59	1.60	1.37
25/09/2024	1.61	1.40	1.53	1.16
26/09/2024	1.56	1.43	1.64	1.56
27/09/2024	1.65	1.45	1.66	1.60
28/09/2024	1.67	1.51	1.70	1.58
29/09/2024	1.63	1.42	1.69	1.54
30/09/2024	1.64	1.47	1.69	1.57

Total Number of Measurements, A: **20885** 20883Minimum Free Chlorine Standard: **0.5** 0.5Number of Measurements Meeting Standard, B: **20885** 20883COMPLIANCE, C = B/A X 100%: **100.00** 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2024\09-September

Submitted By (Print): D. MerredewSignature: original signed by D. Merredew



Water Treatment Plant Chlorine Grab Monitoring Report
September 2024

Water System Code: 252.00		Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Licence No. PWS-09-412-02 AA		Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)
Date		Analyser	Grab	Grab	Analyser	Grab	Grab
01-Sep-2024		ns	ns	ns	ns	ns	ns
02-Sep-2024		ns	ns	ns	ns	ns	ns
03-Sep-2024		1.36	1.39	1.61	1.34	1.39	1.61
04-Sep-2024		1.45	1.50	1.66	1.46	1.42	1.70
05-Sep-2024		1.61	1.63	1.83	1.53	1.53	1.70
06-Sep-2024		1.60	1.65	1.91	1.62	1.66	1.92
07-Sep-2024		ns	ns	ns	ns	ns	ns
08-Sep-2024		ns	ns	ns	ns	ns	ns
09-Sep-2024		1.52	1.58	1.78	1.51	1.52	1.78
10-Sep-2024		1.68	1.81	2.05	1.68	1.80	2.03
11-Sep-2024		1.60	1.74	1.96	1.71	1.74	1.96
12-Sep-2024		1.67	1.81	2.00	1.78	1.77	1.98
13-Sep-2024		1.77	1.82	2.03	1.75	1.80	2.02
14-Sep-2024		ns	ns	ns	ns	ns	ns
15-Sep-2024		ns	ns	ns	ns	ns	ns
16-Sep-2024		1.61	1.62	1.86	1.66	1.68	1.88
17-Sep-2024		1.50	1.51	1.71	1.56	1.50	1.72
18-Sep-2024		1.44	1.48	1.72	1.29	1.35	1.60
19-Sep-2024		1.51	1.61	1.84	1.51	1.52	1.77
20-Sep-2024		1.55	1.59	1.82	1.49	1.53	1.74
21-Sep-2024		ns	ns	ns	ns	ns	ns
22-Sep-2024		ns	ns	ns	ns	ns	ns
23-Sep-2024		1.78	1.79	1.88	1.58	1.59	1.83
24-Sep-2024		1.83	1.88	2.05	1.69	1.78	2.03
25-Sep-2024		1.61	1.59	1.91	1.51	1.58	1.79
26-Sep-2024		1.57	1.47	1.73	1.65	1.60	1.71
27-Sep-2024		1.64	1.64	1.88	1.69	1.75	2.02
28-Sep-2024		ns	ns	ns	ns	ns	ns
29-Sep-2024		ns	ns	ns	ns	ns	ns
30-Sep-2024		ns	ns	ns	ns	ns	ns
Total number of measurements taken, A:		19			19		
Chlorine Standard for Monitoring Location (mg/L):		0.50			0.50		
Number of measurements meeting standard, B:		19			19		
Compliance with Chlorine Standard, C= B/A X 100%:		100%			100%		

na: not analyzed nr: no result ns: no sample o/l: offline im: instrument maintenance

Comments:

Report Date: October 7, 2024



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-02-AA

WATER TREATMENT PLANT UV REPORT

Report Period: September 2024

Report Created: Tuesday, October 01, 2024

Date	UVR-D100A		UVR-D200A		UVR-D300A		UVR-D400A		UVR-D500A		UVR-D600A		Total		% Volume Treated To Dose
	Water Volume	Total	Water Volume	Total	Water Volume	Total	Water Volume	Total	Water Volume	Total	Water Volume	Total	Water Volume [ML]	Total	To
01/09/2024	0.00	0.00	102.21	102.21	0.00	0.00	0.00	0.00	85.79	85.79	0.00	0.00	188.00	188.00	100.00
02/09/2024	0.00	0.00	103.33	103.33	0.00	0.00	0.00	0.00	86.67	86.67	0.00	0.00	190.00	190.00	100.00
03/09/2024	0.00	0.00	106.09	106.09	0.00	0.00	0.00	0.00	91.03	91.03	0.00	0.00	197.12	197.12	100.00
04/09/2024	0.00	0.00	111.35	111.35	0.00	0.00	0.00	0.00	96.90	96.90	0.00	0.00	208.26	208.26	100.00
05/09/2024	0.00	0.00	112.31	112.31	0.00	0.00	0.00	0.00	97.85	97.85	0.00	0.00	210.16	210.16	100.00
06/09/2024	0.00	0.00	111.48	111.48	0.00	0.00	0.00	0.00	97.07	97.07	0.00	0.00	208.55	208.55	100.00
07/09/2024	0.00	0.00	109.98	109.98	0.00	0.00	0.00	0.00	95.81	95.81	0.00	0.00	205.79	205.79	100.00
08/09/2024	0.00	0.00	109.48	109.48	0.00	0.00	0.00	0.00	95.38	95.38	0.00	0.00	204.87	204.87	100.00
09/09/2024	0.00	0.00	110.40	110.40	0.00	0.00	0.00	0.00	96.73	96.73	0.00	0.00	207.13	207.13	100.00
10/09/2024	0.00	0.00	116.83	116.83	0.00	0.00	0.00	0.00	105.44	105.44	0.00	0.00	222.27	222.27	100.00
11/09/2024	0.00	0.00	118.10	118.10	0.00	0.00	0.00	0.00	106.92	106.92	0.00	0.00	225.02	225.02	100.00
12/09/2024	0.00	0.00	115.56	115.56	0.00	0.00	0.00	0.00	100.50	100.50	0.00	0.00	216.06	216.06	100.00
13/09/2024	0.00	0.00	117.33	117.33	0.00	0.00	0.00	0.00	99.71	99.71	0.00	0.00	217.04	217.04	100.00
14/09/2024	0.00	0.00	117.20	117.20	0.00	0.00	0.00	0.00	99.81	99.81	0.00	0.00	217.00	217.00	100.00
15/09/2024	0.00	0.00	117.06	117.06	0.00	0.00	0.00	0.00	99.96	99.96	0.00	0.00	217.03	217.03	100.00
16/09/2024	0.00	0.00	114.33	114.33	0.00	0.00	0.00	0.00	102.68	102.68	0.00	0.00	217.01	217.01	100.00
17/09/2024	0.00	0.01	60.52	60.52	4.89	4.89	0.00	0.00	104.86	104.86	0.00	0.00	170.27	170.27	100.00
18/09/2024	93.27	93.27	0.19	0.22	67.78	67.78	0.00	0.00	36.04	36.04	0.00	0.00	197.28	197.31	99.98
19/09/2024	100.76	100.76	0.00	0.00	104.29	104.29	0.00	0.00	0.00	0.00	0.00	0.00	205.05	205.05	100.00
20/09/2024	97.05	97.05	0.00	0.00	99.86	99.86	0.00	0.00	0.19	0.20	0.00	0.00	197.09	197.11	99.99
21/09/2024	95.24	95.24	0.00	0.00	97.75	97.75	0.00	0.00	0.00	0.00	0.00	0.00	192.99	192.99	100.00
22/09/2024	95.17	95.17	0.00	0.00	97.87	97.87	0.00	0.00	0.00	0.00	0.00	0.00	193.05	193.05	100.00
23/09/2024	91.98	91.98	0.00	0.00	38.38	43.12	57.63	57.63	0.00	0.00	0.00	0.00	188.00	192.74	97.54
24/09/2024	93.30	93.30	0.00	0.00	0.00	0.00	99.67	99.67	0.00	0.00	0.00	0.00	192.97	192.97	100.00
25/09/2024	53.07	53.07	0.00	0.00	0.00	0.00	89.41	89.41	0.10	0.10	40.95	50.44	183.53	193.02	95.08
26/09/2024	0.00	0.00	0.00	0.00	0.00	0.00	88.41	88.41	0.00	0.00	104.25	104.25	192.65	192.65	100.00
27/09/2024	0.11	0.12	0.00	0.00	0.00	0.00	91.95	91.95	0.00	0.00	108.70	108.70	200.76	200.77	99.99
28/09/2024	0.00	0.00	0.00	0.00	0.00	0.00	94.15	94.15	0.00	0.00	110.85	110.85	205.00	205.00	100.00
29/09/2024	0.00	0.00	0.00	0.00	0.00	0.00	90.18	90.18	0.00	0.00	107.00	107.00	197.17	197.17	100.00
30/09/2024	0.00	0.00	0.00	0.00	0.00	0.00	88.92	88.92	0.00	0.00	106.08	106.08	195.00	195.00	100.00

Total [ML]: 719.94 719.96 1853.76 1853.79 510.83 515.57 700.31 700.31 1699.44 1699.46 577.82 587.31 6062.11 6076.41

Water Volume [%]:

To Dose per reactor

100.00 % 100.00 % 99.08 % 100.00 % 100.00 % 98.38 %

To Dose Total

99.76 %

Notes:

1. Target Log value: 2.00

Submitted By (Print): _D. Merredew_____

Signature: _original signed by D. Merredew_____

Page 1 of 2

CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 WATER SERVICES

Water System Code: 252.00
 Licence Number: PWS-09-412-02-AA

WATER TREATMENT PLANT UV REPORT

Report Period: September 2024

Report Created: Tuesday, October 01, 2024

Date	Transmittance (%)				UVR_D100A [Log]		UVR_D200A [Log]		UVR_D300A [Log]		UVR_D400A [Log]		UVR_D500A [Log]		UVR_D600A [Log]	
	Branch 1		Branch 2		Avg.	Min.										
01/09/2024	96.6	95.9	95.8	95.5	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
02/09/2024	96.7	95.9	95.9	95.6	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
03/09/2024	96.6	95.9	95.8	95.4	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
04/09/2024	96.5	95.7	95.7	95.1	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
05/09/2024	96.4	95.5	95.6	95.3	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
06/09/2024	96.5	95.6	95.6	46.8	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	1.7	OL	OL
07/09/2024	96.5	95.6	95.6	95.2	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
08/09/2024	96.6	95.7	95.7	95.3	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
09/09/2024	96.7	95.0	95.9	94.8	OL	OL	2.5	1.9	OL	OL	OL	OL	2.5	2.1	OL	OL
10/09/2024	96.6	96.0	95.8	95.4	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
11/09/2024	96.6	96.0	95.8	95.4	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
12/09/2024	96.8	95.8	96.0	94.8	OL	OL	2.5	2.0	OL	OL	OL	OL	2.5	2.3	OL	OL
13/09/2024	96.7	96.0	95.9	95.6	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
14/09/2024	96.9	96.1	96.1	95.6	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
15/09/2024	96.9	96.0	96.2	95.8	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
16/09/2024	96.9	96.3	96.1	95.9	OL	OL	2.5	2.3	OL	OL	OL	OL	2.5	2.3	OL	OL
17/09/2024	96.9	96.1	96.1	95.7	1.3	0.0	2.5	2.3	3.8	3.6	OL	OL	2.5	2.2	OL	OL
18/09/2024	96.1	94.8	95.4	94.2	4.1	0.0	3.9	0.0	2.9	0.0	OL	OL	2.5	2.3	OL	OL
19/09/2024	97.0	95.2	96.2	95.8	4.1	4.1	OL	OL	2.5	2.3	OL	OL	OL	OL	OL	OL
20/09/2024	97.0	95.5	96.3	96.0	4.1	4.1	OL	OL	2.5	2.2	OL	OL	4.0	0.0	OL	OL
21/09/2024	97.0	95.4	96.2	0.0	4.1	4.1	OL	OL	2.5	1.7	OL	OL	OL	OL	OL	OL
22/09/2024	97.1	95.7	96.4	96.0	4.1	4.1	OL	OL	2.5	2.3	OL	OL	OL	OL	OL	OL
23/09/2024	96.7	95.0	95.2	0.0	4.1	4.1	OL	OL	2.0	0.0	2.8	2.1	OL	OL	OL	OL
24/09/2024	95.5	94.9	94.7	94.3	4.1	4.1	OL	OL	OL	OL	2.5	2.3	OL	OL	OL	OL
25/09/2024	95.5	94.9	94.6	93.6	4.1	4.1	OL	OL	OL	OL	2.6	2.2	2.5	2.5	2.7	0.0
26/09/2024	95.5	94.8	90.0	0.0	OL	OL	OL	OL	OL	OL	2.5	2.0	OL	OL	2.7	2.2
27/09/2024	95.4	94.8	94.3	0.1	3.7	0.0	OL	OL	OL	OL	2.5	2.3	OL	OL	2.5	2.0
28/09/2024	95.3	94.5	94.3	89.4	OL	OL	OL	OL	OL	OL	2.5	2.2	OL	OL	2.5	2.2
29/09/2024	95.4	94.7	94.3	93.0	OL	OL	OL	OL	OL	OL	2.5	2.3	OL	OL	2.5	2.2
30/09/2024	95.5	94.9	94.5	91.6	OL	OL	OL	OL	OL	OL	2.5	2.3	OL	OL	2.5	2.3

Notes: 1. UV target value is 2.00 [Log]
 2. OL - Off Line

Submitted By (Print): D. Merredew

Signature: original signed by D. Merredew

Page 2 of 2