



Water and Waste Department • Service des eaux et des déchets

February 4, 2014

Our File: 040-18-18-14-00

Dr. Khalida Hai-Santiago c/o Helen Browne
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

Dear Dr. Hai-Santiago:

RE: CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

<u>LOCATION</u>	<u>SAMPLE NUMBER</u>	<u>DATE</u>	<u>RESULT(mg/L F)</u>
Distribution System (Composite – 39 Locations)	383650	January 6, 2014	0.70
	384262	January 13, 2014	0.62
	384952	January 20, 2014	0.50
	385618	January 27, 2014	0.67

On Sunday, January 12, the fluoridation system was shut down due to a chemical leak in the Chemical Feed Building at the Water Treatment Plant which contributed to the low distribution system composite fluoride result. The fluoridation system was put back into service on Wednesday, January 15.

If you have any questions on the foregoing, please call Ms. Renée Grosselle, Supervisor of Compliance Reporting, at 204-986-8359.

Yours truly,

Original signed by :

K.J.T. Kjartanson, P.Eng.
Manager of Environmental Standards Division

RG/kw

cc: Terry Josephson, P.Eng. Manager of Water Services (e-mail)

N:\Compliance Reporting\Submittal Letters\2014\Dental\Dental-January.doc