



Water and Waste Department • Service des eaux et des déchets

January 4, 2017

Our File: 040-18-18-14-00

Dr. Khalida Hai-Santiago c/o Helen Browne  
300 Carlton Street (Room 4068)  
Winnipeg, Manitoba  
R3B 3M9

Dear Dr. Hai-Santiago:

**RE: CITY OF WINNIPEG FLUORIDE MONITORING DATA**

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

<b><u>LOCATION</u></b>	<b><u>SAMPLE NUMBER</u></b>	<b><u>DATE</u></b>	<b><u>RESULT(mg/L F)</u></b>
Distribution System (Composite – 39 Locations)	490969	07-Nov-16	0.64
	491539	14-Nov-16	0.68
	492217	21-Nov-16	0.65
	492821	28-Nov-16	0.68

If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours truly,

*Original signed by:*

Renée Grosselle  
Manager of Environmental Standards

NC/HD

cc: Tim Shanks, P.Eng. Manager of Water Services (e-mail)

N:\Compliance Reporting\Submittal Letters\2016\MB Health - Fluoride\2016-11 Fluoride.doc