



Water and Waste Department • Service des eaux et des déchets
Environmental Standards Division • Division des Normes Environnementales

July 6, 2017

Our File: 040-18-18-14-00

Dr. Khalida Hai-Santiago c/o Helen Browne
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

Dear Dr. Hai-Santiago:

RE: CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

<u>LOCATION</u>	<u>SAMPLE NUMBER</u>	<u>DATE</u>	<u>RESULT (mg/L F)</u>
Distribution System (Composite – 39 Locations)	504769	3-Apr-17	0.65
	505459	10-Apr-17	0.70
	506198	18-Apr-17	0.66
	506948	24-Apr-17	0.53

The fluoridation system was shut down for maintenance from April 19 to April 21, 2017; the low fluoride result on April 24, 2017 was as a result of the shut-down.

If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours truly,

Original signed by:

Renée Grosselle
Manager of Environmental Standards

NC/HD

cc: Tim Shanks, P.Eng. Manager of Water Services (e-mail)

