



Water and Waste Department • Service des eaux et des déchets
Environmental Standards Division • Division des Normes Environnementales

October 4, 2018

Our File: 040-18-18-14-00

Dr. Khalida Hai-Santiago c/o Helen Browne
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

Dear Dr. Hai-Santiago:

RE: CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

LOCATION	SAMPLE NUMBER	DATE	RESULT (mg/L F)
Distribution System (Composite – 39 Locations)	6752	3-Jul-18	0.68
	7613	9-Jul-18	0.68
	10438	16-Jul-18	0.69
	12721	23-Jul-18	0.70
	15306	30-Jul-18	0.69
	17791	6-Aug-18	0.68
	72220	13-Aug-18	0.69
	129696	20-Aug-18	0.69
	135206	27-Aug-18	0.69
	137353	3-Sep-18	0.67
	140049	10-Sep-18	0.68
	142037	17-Sep-18	0.53
	143775	24-Sep-18	0.66

The decreased fluoride concentration on September 17 was due to an interruption in fluoride dosing from September 12-14.

If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours truly,

Original signed by:

Renée Grosselle
Manager of Environmental Standards

NC/HD

cc: Tim Shanks, P.Eng. Manager of Water Services (e-mail)