



Water and Waste Department • Service des eaux et des déchets

February 7, 2013

Our File: 040-18-18-55-00

Ms. Melanie Betsill
Drinking Water Officer
Office of Drinking Water
Manitoba Conservation and Water Stewardship
1007 Century Street
Winnipeg, Manitoba
R3H 0W4

Dear Ms. Betsill:

**RE: LEAD LOOP SYSTEM ANNUAL SUMMARY REPORT
FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM FOR 2012**

Please find attached the Lead Loop System Summary Report for 2012 for the Winnipeg water supply system for your review and records.

As per Section 4.13, Table 2. of the operating licence, we are submitting the required annual lead summary report for the City of Winnipeg water supply system. This is in accordance with the reporting requirements established by the Office of Drinking Water provided in writing on March 1, 2010 by your office. We have been advised that Manitoba Health will be providing their recommendations on the lead protocol and further direction in writing will be provided by your office when the protocol is finalized. Until further direction is provided by your office, we will continue to report the five minute flushed lead concentration results from the lead loop system to meet the March 1 reporting requirement.

Please let me know of any concerns or questions respecting this submission. I may be reached at the below address, by telephone at 204-986-4807 or by e-mail at kkjartanson@winnipeg.ca.

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original signed by:

K.J.T. Kjartanson, P.Eng.
Manager of Environmental Standards

KJTK/RG
Attachments

c: Dr. L. Richards, Winnipeg Regional Health Authority
Dr. S. Roberecki, Manitoba Health
D.P. Sacher, P.Eng. (e-mail)
T. Josephson, P.Eng.
S. Fletcher

N:\Compliance Reporting\Submittal Letters\2012\Lead Report 2012 Annual Summary Final.doc



**CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION**

Water System Code: 252.00

Licence Number: PWS-09-412 A

2012 Lead Loop System Summary Report

SAMPLE DATE	Five minute flushed Lead Concentration (mg/L)				
	Lead Loop Cu	Lead Loop Pb	Lead Loop Pb1	Lead Loop Pb2	Lead Loop Pb3
January 24, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
February 23, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
March 13, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
April 17, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
May 11, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
June 13, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
July 18, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
August 15, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
September 12, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
October 17, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
November 15, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
December 12, 2012	<0.001	<0.001	<0.001	<0.001	<0.001
2012 AVERAGE LEAD CONCENTRATION	<0.001	<0.001	<0.001	<0.001	<0.001

COMMENTS:

NS - NO SAMPLE
NR - NO RESULT

Report Compiled By: J. Jones

Approved in LIMS By: S.Fletcher

Date Approved: 17-Dec-12

Methodology

Reference Method for Lead: Standard Methods for the Examination of Water and Wastewater, 2nd Edition, Method 3125