



Water and Waste Department • Service des eaux et des déchets

June 6, 2014

Our File: 040-18-18-55-00

Melanie Betsill
Office of Drinking Water
Manitoba Conservation and Water Stewardship
1007 Century Street
Winnipeg, Manitoba
R3H 0W4

Dear Ms. Betsill:

**RE: TOTAL TRIHALOMETHANE SUMMARY REPORT
FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM FOR QUARTER 2 - 2014**

Please find attached the Total Trihalomethane Summary Report for the second quarter of 2014 for the Winnipeg water supply system for your review and records.

Please let me know of any concerns or questions respecting this submission. I may be reached at the below address, by telephone at 204-986-4807 or by e-mail at kkjartanson@winnipeg.ca.

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original signed by:

K.J.T. Kjartanson, P.Eng.
Manager of Environmental Standards

KJTK/rg
Attachments

c: Dr. L. Richards, Winnipeg Regional Health Authority
Dr. S. Roberecki, Manitoba Health
D.P. Sacher, P.Eng. (e-mail)
G. Patton, P.Eng. (e-mail)
T. Shanks, P.Eng. (e-mail)
S. Fletcher (e-mail)

N:\Compliance Reporting\Submittal Letters\2014\THM\Quarter 2-2014 THM Submittal Letter.doc

Embrace the spirit • Vivez l'esprit

Environmental Standards Division • Division des normes environnementales
2230 Main Street • 2230, Rue Main • Winnipeg • Manitoba R2V 4T8
tel/tél. (204) 986-4684 • fax/télec. (204) 339-2147 • www.winnipeg.ca

**CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION**

Total Trihalomethane Summary Report

Reporting Period: Quarter 2 2014

SAMPLE DATE	DISTRIBUTION SYSTEM THM RESULTS (ug/L)					
Monday, August 12, 2013	31	37	30	40	42	37
Monday, November 04, 2013	14	14	14	17	17	16
Monday, February 10, 2014	13	13	13	14	13	13
Monday, May 05, 2014	13	12	12	13	13	14
RUNNING AVERAGE THM	18	19	17	21	21	20

COMMENTS:

NS - NO SAMPLE
NR - NO RESULT

Methodology

Trihalomethanes analyzed by GC-ECD, Standard Methods for the Examination of Water and Waste Water, 21st Edition, Method 6232

Report Compiled by: H.Demchenko

Approved in LIMS by: S.Fletcher

File: WQR4

Date Approved: June 2, 2014

N:\Environmental Standards\Analytical Services\WQ Data\Routine Water Quality\2014\Quarterly THM\[Quarterly THM 2014.xls]THM Q2