

January 20, 2021

**2020 Annual Compliance Audit**

<b>Water System:</b> WINNIPEG - PWS	<b>Code:</b> 252.00
<b>Water System Owner:</b> City of Winnipeg	<b>Address:</b> 101-1199 Pacific Ave, Winnipeg, MB R3E 3S8
<b>Operating Licence:</b> PWS-09-412-01	<b>Expiry Date:</b> November 30, 2020
<b>Water System Assessment Due Date:</b> March 1, 2022	
<b>Public Water System Annual Report Due Date:</b> March 31, 2021	<b>Advisory Notification Plan Due Date:</b> May 1, 2021

- 1) This report documents compliance of the Winnipeg Public Water System for the period from January 1 to December 31, 2020.
- 2) This report provides specific information on the non-compliance incidents identified in the summary below.
- 3) Other than the information provided in this report, the water supplier has complied with The Drinking Water Safety Act, its supporting regulations, and the terms and conditions of the water system's current operating licence.
- 4) This report is based on information submitted by the water supplier, agents of the water supplier, and / or the Province of Manitoba.
- 5) Where non-compliance items are identified, the issues do not necessarily translate into increased public health risk. The Office of Drinking Water uses processes, including boil water advisories, to notify water users of a public health risk.

**Non-compliance with Treatment Standards:**

*Water system was compliant in the audited time period.*

## Non-compliance Incidents:

Date	Incident	Outcome
September	Failure to maintain a free chlorine residual of at least 0.5 mg/L in accordance with the operating licence	Non-compliant
2020-09-21	Failure to meet Bacteriological Standard: Total Coliform (TC) detected	Non-compliant
September	Failure to maintain below 1.0 NTU at all times	Non-compliant
September	Failure to maintain below 1.0 NTU at all times	Non-compliant

If you have any questions, please do not hesitate to contact me at (204) 795-6908.

Sincerely,



Kale Black  
Senior Regional Drinking Water Officer